

OIL ANALYSIS REPORT



Machine Id

003-111086 Component Compressor

Compressor Fluid QUINSYN PRIME (--- QTS)

DIAGNOSIS

A Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

A Wear

The copper level is abnormal. All other component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC06175632		
Sample Date		Client Info		28 Apr 2024		
Machine Age	hrs	Client Info		48557		
Oil Age	hrs	Client Info		7		
Oil Changed		Client Info		Not Changd		
Sample Status				ABNORMAL		
CONTAMINATION	J	method	limit/base	current	historv1	historv2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	43		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	1		
Copper	ppm	ASTM D5185m	>50	<u> </u>		
Tin	ppm	ASTM D5185m	>15	2		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		600		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		2		
Calcium	ppm	ASTM D5185m		6		
Phosphorus	ppm	ASTM D5185m		23		
Zinc	ppm	ASTM D5185m		23		
Sulfur	ppm	ASTM D5185m		442		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3		
Sodium	ppm	ASTM D5185m		35		
Potassium	ppm	ASTM D5185m	>20	4		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.29		



50

40

30

10

0

0.3 (B/HO)

문0.18

e 0.12

90.0

52

50 48 (J°0€) (10°0

ي بي 44

42

40 Abnorma

38

Apr28/24

nr28/2

OIL ANALYSIS REPORT



CPP 8701 HARRIET AVE S **BLOOMINGTON, MN** US 55420 Contact: Service Manager

Test Package : IND 2 Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

Lab Number : 06175632

Unique Number : 11021685

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Tested

Diagnosed

: 13 May 2024

: 13 May 2024 - Doug Bogart

Report Id: CPPBLO [WUSCAR] 06175632 (Generated: 05/13/2024 15:29:41) Rev: 1

Contact/Location: Service Manager - CPPBLO Page 2 of 2

T:

F:

history2

history2

history2

no image

no image