




# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Machine Id  
**7791254 (S/N 1576)**

Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

### DIAGNOSIS

#### ▲ Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### ▲ Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>KCPA017553</b>	KCPA000725	KCP51352D
Sample Date	Client Info			<b>06 May 2024</b>	14 Sep 2023	16 May 2022
Machine Age	hrs	Client Info		<b>4164</b>	2787	1082
Oil Age	hrs	Client Info		<b>0</b>	0	1082
Oil Changed	Client Info			<b>Changed</b>	N/A	Not Changd
Sample Status				<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>0</b>	<1	0
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	0	<1
Nickel	ppm	ASTM D5185m	>3	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m	>3	<b>0</b>	0	<1
Silver	ppm	ASTM D5185m	>2	<b>0</b>	0	1
Aluminum	ppm	ASTM D5185m	>10	<b>0</b>	0	<1
Lead	ppm	ASTM D5185m	>10	<b>&lt;1</b>	0	<1
Copper	ppm	ASTM D5185m	>50	<b>5</b>	8	<1
Tin	ppm	ASTM D5185m	>10	<b>&lt;1</b>	<1	<1
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	<1
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	<1






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	90	<b>&lt;1</b>	0	16
Molybdenum	ppm	ASTM D5185m	0	<b>0</b>	<1	<1
Manganese	ppm	ASTM D5185m		<b>0</b>	<1	2
Magnesium	ppm	ASTM D5185m	100	<b>23</b>	29	64
Calcium	ppm	ASTM D5185m	0	<b>0</b>	2	0
Phosphorus	ppm	ASTM D5185m	0	<b>1</b>	4	3
Zinc	ppm	ASTM D5185m	0	<b>12</b>	2	0
Sulfur	ppm	ASTM D5185m	23500	<b>21002</b>	22090	23392

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>2</b>	<1	2
Sodium	ppm	ASTM D5185m		<b>6</b>	9	4
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	2	<1
Water	%	ASTM D6304	>0.05	<b>0.009</b>	0.017	▲ 0.558
ppm Water	ppm	ASTM D6304	>500	<b>96</b>	174.9	▲ 5580

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		<b>51306</b>	---	---
Particles >6µm		ASTM D7647	>1300	▲ <b>27403</b>	---	---
Particles >14µm		ASTM D7647	>80	▲ <b>1015</b>	---	---
Particles >21µm		ASTM D7647	>20	▲ <b>36</b>	---	---
Particles >38µm		ASTM D7647	>4	<b>1</b>	---	---
Particles >71µm		ASTM D7647	>3	<b>0</b>	---	---
Oil Cleanliness		ISO 4406 (c)	>--/17/13	▲ <b>23/22/17</b>	---	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	<b>0.31</b>	0.30	0.37


# OIL ANALYSIS REPORT







PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	● HAZY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	▲ 0.2%
Free Water	scalar	*Visual		NEG	▲ 1.0

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	44.6	43.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA017553  
**Lab Number** : 06176100  
**Unique Number** : 11022153  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )  
**Received** : 10 May 2024  
**Tested** : 14 May 2024  
**Diagnosed** : 14 May 2024 - Doug Bogart

**HOME FOOD SERVICE**  
 12 HEADBY PLACE  
 FALLSINGTON, PA  
 US 19054  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)