

# **OIL ANALYSIS REPORT**

Sample Rating Trend **WEAR** 

Machine Id KAESER CSD 100S 6649381 (S/N 1253) Component Compressor

Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

# DIAGNOSIS

#### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

## 🔺 Wear

The copper level is abnormal. All other component wear rates are normal.

#### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016515	KCPA006973	KCP47607
Sample Date		Client Info		24 Apr 2024	08 Nov 2023	10 Nov 2022
Machine Age	hrs	Client Info		15953	13938	11893
Oil Age	hrs	Client Info		4892	0	842
Oil Changed		Client Info		Changed	N/A	Not Changd
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	1
Titanium	ppm	ASTM D5185m	>3	0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m		0	1	5
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m		▲ 61	33	23
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Vanadium	ppm	ASTM D5185m	- 10	0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	1	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	90	2	<1	39
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		0	15	8
Zinc	ppm	ASTM D5185m		132	137	161
Sulfur	ppm	ASTM D5185m		20353	19933	21922
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	<1
Sodium	ppm	ASTM D5185m		1	0	9
Potassium	ppm	ASTM D5185m	>20	0	1	6
Water	%	ASTM D6304	>0.05	0.003	0.005	0.014
ppm Water	ppm	ASTM D6304	>500	26	59	144.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		655	850	3720
Particles >6µm		ASTM D7647	>1300	140	182	1014
Particles >14µm		ASTM D7647	>80	19	17	72
Particles >21µm		ASTM D7647	>20	8	6	22
Particles >38µm		ASTM D7647	>4	1	0	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/14/11	17/15/11	19/17/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2


Contact/Location: J. STILES - LONALP Page 1 of 2





Built for a lifetime


# **OIL ANALYSIS REPORT**













Color



Bottom



\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: LONALP [WUSCAR] 06176106 (Generated: 05/14/2024 14:22:08) Rev: 1

Certificate 12367

Contact/Location: J. STILES - LONALP Page 2 of 2

T:

F: