


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 

Machine Id

# KAESER SK20 8363665 (S/N 2230)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

#### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Sep2022	Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017154	KCP50661	
Sample Date		Client Info		23 Apr 2024	22 Sep 2022	
Machine Age	hrs	Client Info		8230	2153	
Oil Age	hrs	Client Info		8230	2153	
Oil Changed		Client Info		Changed	Not Changd	
Sample Status				NORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	32	9	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	<1	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	100	10	46	
Calcium	ppm	ASTM D5185m	0	0	<1	
Phosphorus	ppm	ASTM D5185m	0	0	4	
Zinc	ppm	ASTM D5185m	0	44	12	
Sulfur	ppm	ASTM D5185m	23500	20471	21017	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	
Sodium	ppm	ASTM D5185m		6	11	
Potassium	ppm	ASTM D5185m	>20	<1	6	
Water	%	ASTM D6304	>0.05	0.010	0.020	
ppm Water	ppm	ASTM D6304	>500	104	200.9	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2584	21909	
Particles >6μm		ASTM D7647		810	<u>^</u> 7494	
Particles >14µm		ASTM D7647	>80	53	<u>1321</u>	
Particles >21µm		ASTM D7647		11	<u>457</u>	
Particles >38µm		ASTM D7647	>4	0	<u>^</u> 26	
Particles >71μm		ASTM D7647		0	1	
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/13	<u>22/20/18</u>	
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.33	0.32	



## OIL ANALYSIS REPORT







Laboratory Sample No.

: KCPA017154 Lab Number : 06176123 Unique Number : 11022176

Received **Tested** Diagnosed

: 10 May 2024 : 14 May 2024 : 14 May 2024 - Doug Bogart

7137 SOUTH LAKE PKWY, SUITE B

MORROW, GA US 30260 Contact: SERVICE MANAGER

kwasigray@ups.com

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: SERVICE MANAGER - UPSMOR

T:

F: