




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
EVA CREEK
 Machine Id
WEC 3 - 92031 (S/N 25230)
 Component
Wind Turbine Gearbox
 Fluid
CASTROL OPTIGEAR SYNTHETIC A ISO 320 (475 GAL)

DIAGNOSIS

Recommendation

The oil change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

Gear wear is indicated.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0634824	WC0634816	WC0544196
Sample Date	Client Info	21 Mar 2024	12 May 2022	03 Aug 2021
Machine Age	hrs	30115	76133	72294
Oil Age	hrs	0	0	72294
Oil Changed	Client Info	Changed	N/A	Not Changd
Sample Status		ABNORMAL	NORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2		
PQ	ASTM D8184	>80	20	25	19	
Iron	ppm	ASTM D5185m	>70	81	85	86
Chromium	ppm	ASTM D5185m	>3	<1	1	1
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m	>10	0	0	<1
Silver	ppm	ASTM D5185m		0	<1	0
Aluminum	ppm	ASTM D5185m	>9	13	2	1
Lead	ppm	ASTM D5185m	>9	0	<1	<1
Copper	ppm	ASTM D5185m	>25	<1	3	3
Tin	ppm	ASTM D5185m	>9	<1	0	<1
Antimony	ppm	ASTM D5185m	>5	---	---	0
Vanadium	ppm	ASTM D5185m		<1	<1	<1
Cadmium	ppm	ASTM D5185m		<1	0	<1

ADDITIVES

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185m	0	29	2	5
Barium	ppm	ASTM D5185m	0	5	4	0
Molybdenum	ppm	ASTM D5185m	1150	1054	1164	1272
Manganese	ppm	ASTM D5185m		2	2	2
Magnesium	ppm	ASTM D5185m	1800	1811	1802	1929
Calcium	ppm	ASTM D5185m	20	14	14	15
Phosphorus	ppm	ASTM D5185m	1450	1554	1413	1517
Zinc	ppm	ASTM D5185m	1650	1662	1675	1757
Sulfur	ppm	ASTM D5185m	4900	7060	5702	5563

CONTAMINANTS






method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185m	>33	13	16	16
Sodium	ppm	ASTM D5185m	>20	9	6	7
Potassium	ppm	ASTM D5185m	>20	<1	0	2
Water	%	ASTM D6304	>.110	0.018	0.061	0.029
ppm Water	ppm	ASTM D6304	>1100	186	610.8	295.3

FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>2500	▲ 39361	1298	---
Particles >6µm	ASTM D7647	>640	● 1252	97	---
Particles >14µm	ASTM D7647	>80	5	8	---
Particles >21µm	ASTM D7647	>20	2	2	---
Particles >38µm	ASTM D7647	>4	0	1	---
Particles >71µm	ASTM D7647	>3	0	1	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 22/17/10	17/14/10	---



OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	3.3	2.34	2.06	2.205






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	▲ MODER
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.110	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	305	334	335	331

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0634824 **Received** : 10 May 2024
Lab Number : 06176149 **Tested** : 16 May 2024
Unique Number : 11022202 **Diagnosed** : 16 May 2024 - Angela Borella
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

GOLDEN VALLEY ELECTRIC
 MILE 2.5 HEALY SPUR RD
 HEALY, AK
 US 99743
 Contact: RYAN DEWITT
 rjdewitt@gvea.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)