




OIL ANALYSIS REPORT

Sample Rating Trend



ADDITIVES



Area

EVA CREEK

Machine Id

WEC 10 - 91976 (S/N 32634)

Component

Wind Turbine Gearbox

Fluid

CASTROL OPTIGEAR SYNTHETIC A ISO 320 (475 GAL)

DIAGNOSIS

Recommendation

We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. Calcium and/or magnesium levels higher than normal indicating possible contamination

Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0634825	WC0544193	WC0373047
Sample Date	Client Info		01 May 2024	04 Jun 2021	18 Aug 2020
Machine Age	hrs	Client Info	29813	69667	68277
Oil Age	hrs	Client Info	0	69667	68277
Oil Changed	Client Info		N/A	Not Changd	Not Changd
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
PQ	ASTM D8184	>80	19	25	20	
Iron	ppm	ASTM D5185m	>70	26	144	131
Chromium	ppm	ASTM D5185m	>3	0	2	2
Nickel	ppm	ASTM D5185m	>2	0	0	<1
Titanium	ppm	ASTM D5185m	>10	0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>9	16	1	14
Lead	ppm	ASTM D5185m	>9	0	<1	1
Copper	ppm	ASTM D5185m	>25	<1	3	3
Tin	ppm	ASTM D5185m	>9	<1	<1	0
Antimony	ppm	ASTM D5185m	>5	---	0	6
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	37	6	<1
Barium	ppm	ASTM D5185m	0	5	<1	2
Molybdenum	ppm	ASTM D5185m	1150	1360	1253	1109
Manganese	ppm	ASTM D5185m		<1	2	2
Magnesium	ppm	ASTM D5185m	1800	1796	1936	1730
Calcium	ppm	ASTM D5185m	20	221	14	13
Phosphorus	ppm	ASTM D5185m	1450	1533	1482	1175
Zinc	ppm	ASTM D5185m	1650	1634	1714	1412
Sulfur	ppm	ASTM D5185m	4900	7339	5887	4647

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>33	23	16	12
Sodium	ppm	ASTM D5185m	>20	5	7	6
Potassium	ppm	ASTM D5185m	>20	0	4	0
Water	%	ASTM D6304	>.110	0.012	0.068	0.040
ppm Water	ppm	ASTM D6304	>1100	124	683.9	404.2


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	46331	14815	9581
Particles >6µm	ASTM D7647	>640	311	489	1008
Particles >14µm	ASTM D7647	>80	11	10	6
Particles >21µm	ASTM D7647	>20	4	1	2
Particles >38µm	ASTM D7647	>4	1	0	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	23/15/11	21/16/10	20/17/10




OIL ANALYSIS REPORT


Particle Trend




Additives




Water (KF)



PQ



Water (KF)




FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D8045 3.3	3.11	2.249	2.705
VISUAL				
method	limit/base	current	history1	history2
White Metal scalar	*Visual NONE	NONE	NONE	NONE
Yellow Metal scalar	*Visual NONE	NONE	NONE	NONE
Precipitate scalar	*Visual NONE	NONE	NONE	NONE
Silt scalar	*Visual NONE	NONE	NONE	NONE
Debris scalar	*Visual NONE	NONE	LIGHT	NONE
Sand/Dirt scalar	*Visual NONE	NONE	NONE	NONE
Appearance scalar	*Visual NORML	NORML	NORML	NORML
Odor scalar	*Visual NORML	NORML	NORML	NORML
Emulsified Water scalar	*Visual >.110	NEG	NEG	NEG
Free Water scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES


method	limit/base	current	history1	history2
Visc @ 40°C cSt	ASTM D445 305	334	332	329

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0634825

Lab Number : 06176151

Unique Number : 11022204

Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received : 10 May 2024

Tested : 16 May 2024

Diagnosed : 16 May 2024 - Angela Borella

GOLDEN VALLEY ELECTRIC

MILE 2.5 HEALY SPUR RD

HEALY, AK

US 99743

Contact: RYAN DEWITT

rjdewitt@gvea.com

T:

F: