




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
(EQ5150) W
 Machine Id
Brockport Tank (S/N EEIOH706466)
 Component
Diesel Engine
 Fluid
KENDALL SHP 5W40 Diesel Engine Oil (32 QTS)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0934074	WC0810892	WC0696113
Sample Date	Client Info		08 May 2024	18 May 2023	11 May 2022
Machine Age	hrs	Client Info	193	173	145
Oil Age	hrs	Client Info	193	173	145
Oil Changed	Client Info		Not Changed	Not Changed	Not Changed
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>5	<1.0	<1.0	<1.0
Water	WC Method	>0.2	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >100	6	5	6
Chromium	ppm	ASTM D5185m >20	<1	0	<1
Nickel	ppm	ASTM D5185m >4	0	0	0
Titanium	ppm	ASTM D5185m	22	22	22
Silver	ppm	ASTM D5185m >3	0	0	0
Aluminum	ppm	ASTM D5185m >20	1	<1	1
Lead	ppm	ASTM D5185m >40	6	5	5
Copper	ppm	ASTM D5185m >330	8	6	7
Tin	ppm	ASTM D5185m >15	<1	<1	<1
Antimony	ppm	ASTM D5185m	---	---	---
Vanadium	ppm	ASTM D5185m	<1	0	<1
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	93	100	101
Barium	ppm	ASTM D5185m	3	0	0
Molybdenum	ppm	ASTM D5185m	102	97	102
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	69	3	8
Calcium	ppm	ASTM D5185m	1953	1867	1901
Phosphorus	ppm	ASTM D5185m	677	645	658
Zinc	ppm	ASTM D5185m 1288	816	736	759
Sulfur	ppm	ASTM D5185m	3204	2819	2545

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	13	12	12
Sodium	ppm	ASTM D5185m	2	1	<1
Potassium	ppm	ASTM D5185m >20	2	2	<1

INFRA-RED




	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844 >3	0	0	0.1
Nitration	Abs/cm	*ASTM D7624 >20	5.5	5.3	4.9
Sulfation	Abs/.1mm	*ASTM D7415 >30	14.9	14.8	14.0

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	8.9	8.6	8.0
Base Number (BN)	mg KOH/g	ASTM D2896 10.2	4.4	4.4	4.4











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.5	12.6	12.8

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0934074 **Received** : 13 May 2024
Lab Number : **06176914** **Tested** : 14 May 2024
Unique Number : 11022967 **Diagnosed** : 14 May 2024 - Sean Felton
Test Package : MOB 1 (Additional Tests: TBN)

MONROE COUNTY WATER AUTHORITY
 4799 DEWEY AVE
 ROCHESTER, NY
 US 14612
 Contact: SCOTT TRAIL
 scott.trail@mcwa.com
 T: (585)775-5257
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)