




OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
KAESER AS 30 5947507 (S/N 1398)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a light concentration of water present in the oil. High concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | | KCPA017305 | KCP53646 | KCP47935D |
| Sample Date | Client Info | | | 07 May 2024 | 03 May 2023 | 15 Nov 2022 |
| Machine Age | hrs | Client Info | | 22834 | 19065 | 17856 |
| Oil Age | hrs | Client Info | | 0 | 3000 | 2094 |
| Oil Changed | Client Info | | | Changed | Changed | Changed |
| Sample Status | | | | ABNORMAL | ATTENTION | ABNORMAL |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|-------------|------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m | >50 | 0 | 0 | 3 |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >2 | 0 | 0 | <1 |
| Aluminum | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Lead | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185m | >50 | 16 | 10 | 9 |
| Tin | ppm | ASTM D5185m | >10 | <1 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |




| ADDITIVES | | method | limit/base | current | history1 | history2 |
|------------|-----|-------------|------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | 0 | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | 90 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | 1 | 0 | 0 |
| Magnesium | ppm | ASTM D5185m | 100 | 0 | 4 | <1 |
| Calcium | ppm | ASTM D5185m | 0 | <1 | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | 0 | 0 | 0 | 24 |
| Zinc | ppm | ASTM D5185m | 0 | 0 | 3 | 0 |
| Sulfur | ppm | ASTM D5185m | 23500 | 18430 | 18786 | 18942 |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|-------------|------------|----------------|----------|----------|
| Silicon | ppm | ASTM D5185m | >25 | <1 | 0 | <1 |
| Sodium | ppm | ASTM D5185m | | <1 | 0 | 0 |
| Potassium | ppm | ASTM D5185m | >20 | 0 | <1 | 0 |
| Water | % | ASTM D6304 | >0.05 | ▲ 0.127 | 0.007 | 0.011 |
| ppm Water | ppm | ASTM D6304 | >500 | ▲ 1270 | 76.4 | 113.2 |

| FLUID CLEANLINESS | | method | limit/base | current | history1 | history2 |
|-------------------|--|--------------|------------|---------|------------|------------|
| Particles >4µm | | ASTM D7647 | | --- | 6092 | 201294 |
| Particles >6µm | | ASTM D7647 | >1300 | --- | ● 1612 | ▲ 72377 |
| Particles >14µm | | ASTM D7647 | >80 | --- | ● 98 | ▲ 3423 |
| Particles >21µm | | ASTM D7647 | >20 | --- | ● 25 | ▲ 665 |
| Particles >38µm | | ASTM D7647 | >4 | --- | 1 | ▲ 18 |
| Particles >71µm | | ASTM D7647 | >3 | --- | 0 | 0 |
| Oil Cleanliness | | ISO 4406 (c) | >--/17/13 | --- | ● 20/18/14 | ▲ 25/23/19 |

| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|-------------------|----------|------------|------------|--------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 1.0 | 0.398 | 0.35 | 0.37 |


OIL ANALYSIS REPORT







| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | ▲ HEAVY | NONE | LIGHT |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | ● HAZY | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | 0.2% | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 45 | 51.7 | 49.8 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA017305 **Received** : 13 May 2024
Lab Number : 06177116 **Tested** : 16 May 2024
Unique Number : 11023169 **Diagnosed** : 16 May 2024 - Angela Borella
Test Package : IND 2 (Additional Tests: KF, PrtCount)

FRICKS COMPANY
 101 GOFORTH RD
 FORT WORTH, TX
 US 76126
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: