

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER SM 10 8821479 (S/N 1854)

Component Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC121272		
Sample Date		Client Info		22 Mar 2024		
Machine Age	hrs	Client Info		7983		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m		0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m		<1		
Lead	ppm	ASTM D5185m	>10	<1		
Copper	ppm	ASTM D5185m		8		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	27		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		1		
Magnesium	ppm	ASTM D5185m	90	57		
Calcium	ppm	ASTM D5185m	2	0		
Phosphorus	ppm	ASTM D5185m		0		
Zinc	ppm	ASTM D5185m		0		
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		15		
Potassium	ppm	ASTM D5185m	>20	1		
Water	%	ASTM D6304	>0.05	0.020		
ppm Water	ppm	ASTM D6304	>500	207		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		14165		
Particles >6µm		ASTM D7647	>1300	<u> </u>		
Particles >14µm		ASTM D7647	>80	A 116		
Particles >21µm		ASTM D7647		A 33		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647		0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>		
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.34		
	mynony	, 10 I M D0040	0	0.04		



Particle Trend

16k 144

12k

8k

4k

2

0

12000

1000

800 (maa)

600 Water 400

200

0.50

(B/HOX Ê0.3

E 0.20

Pio 0.1

0.00

1000

600 Water (

4000

200

52

5

48

(D=04) 44 B

42

38

Abno 4(

1000ml

Water (KF)

Acid Number

Water (KF)


Abnormal n Aar22/

Viscosity @ 40°C

mber of particles () 4 9 88 89 88

Built for a lifetime

14µm





Report Id: VERTAM [WUSCAR] 06177147 (Generated: 05/14/2024 19:37:25) Rev: 1

Contact/Location: Service Manager - VERTAM