


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

8915962 (S/N 1403)

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		<u>, </u>	Nov2023	Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC121865	KC124267	
Sample Date		Client Info		02 Apr 2024	04 Nov 2023	
Machine Age	hrs	Client Info		7726	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	1	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	13	4	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		1	0	
Magnesium	ppm	ASTM D5185m	90	0	8	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		2	6	
Zinc	ppm	ASTM D5185m		0	10	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	0	
Sodium	ppm	ASTM D5185m		1	6	
Potassium	ppm	ASTM D5185m	>20	0	2	
Water	%	ASTM D6304	>0.05	0.006	0.008	
ppm Water	ppm	ASTM D6304	>500	66	82	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		5224	502	
Particles >6µm		ASTM D7647	>1300	<u> </u>	152	
Particles >14μm		ASTM D7647	>80	△ 306	22	
Particles >21µm		ASTM D7647	>20	<u> </u>	8	
Particles >38μm		ASTM D7647	>4	<u> </u>	0	
Particles >71µm		ASTM D7647	>3	1	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/15	16/14/12	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A		AOTAA DOO 45	0.4		0.00	

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.33

0.40



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

: KC121865 Lab Number : 06177160 Unique Number : 11023213 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 13 May 2024 **Tested** : 21 May 2024

Diagnosed : 21 May 2024 - Jonathan Hester

US 18109 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

METEM - A GE POWER CO

404 UNION BLVD

ALLENTOWN, PA

T:

F: