


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

8394493 (S/N 1033)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

				Feb2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA015866		
Sample Date		Client Info		21 Feb 2024		
Machine Age	hrs	Client Info		5782		
Oil Age	hrs	Client Info		5782		
Oil Changed		Client Info		Changed		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	<1		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	5		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium		ASTM D5185m	>10	0		
Cadmium	ppm	ASTM D5185m		0		
Gaumum	ppm	ASTIVI DOTOSIII		U		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	99		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		1		
Magnesium	ppm	ASTM D5185m	90	112		
Calcium	ppm	ASTM D5185m	2	2		
Phosphorus	ppm	ASTM D5185m		0		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		17646		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1		
Sodium	ppm	ASTM D5185m		15		
Potassium	ppm	ASTM D5185m	>20	<1		
Water	%	ASTM D6304	>0.05	△ 0.768		
ppm Water	ppm	ASTM D6304	>500	<u>▲</u> 7681		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		12418		
Particles >6µm		ASTM D7647	>1300	<u>^</u> 2704		
Particles >14μm		ASTM D7647	>80	<u> </u>		
Particles >21µm		ASTM D7647	>20	13		
Particles >38μm		ASTM D7647	>4	1		
Particles >71μm		ASTM D7647	>3	1		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/19/14		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.40		

Contact/Location: DANIEL MAHAN - AMSBOI



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No.

: KCPA015866 Lab Number : 06177164 Unique Number : 11023217

Received Tested Diagnosed

: 13 May 2024 : 14 May 2024 Test Package : IND 2 (Additional Tests: KF, PrtCount)

: 14 May 2024 - Don Baldridge

US 83702 Contact: DANIEL MAHAN daniel.mahan@ams-osram.com

1100 W IDAHO ST, SUITE 430

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Report Id: AMSBOI [WUSCAR] 06177164 (Generated: 05/14/2024 19:46:08) Rev: 1

Contact/Location: DANIEL MAHAN - AMSBOI

BOISE, ID

T:

F: