


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



Machine Id

# HS5 12 (S/N S0075SFMCTHAA03)

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		ar2017 May201:	8 Feb 2019 Oct 2019 Apr 202	0 Jan2021 Aug2021 May2022 Mar20	123 Jan 2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0011432	USP0005475	USP0001114
Sample Date		Client Info		12 May 2024	31 Jan 2024	15 Oct 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	0	0
Chromium	ppm	ASTM D5185m	>2	<1	0	0
Nickel	ppm	ASTM D5185m		0	0	<1
Titanium	ppm	ASTM D5185m		<1	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	0
Lead	ppm	ASTM D5185m	>2	<1	<1	<1
Copper	ppm	ASTM D5185m	>8	<1	0	0
Tin	ppm	ASTM D5185m	>4	<1	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		1	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	0	1
Calcium	ppm	ASTM D5185m		0	0	1
Phosphorus	ppm	ASTM D5185m		0	0	<1
Zinc	ppm	ASTM D5185m		2	0	<1
Sulfur	ppm	ASTM D5185m	50	0	0	8
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1	<1
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	1	0	1
Water	%	ASTM D6304	>0.01	0.003	0.003	0.003
ppm Water	ppm	ASTM D6304	>100	32	37	39.3
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	9794	5086	<u>▲</u> 88757
Particles >6µm		ASTM D7647	>2500	2355	1255	<u>▲</u> 18245
Particles >14µm		ASTM D7647	>320	58	42	<u></u> 556
Particles >21µm		ASTM D7647	>80	8	7	<u></u> 88
Particles >38µm		ASTM D7647	>20	0	1	1
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	20/18/13	20/17/13	<u>4</u> 24/21/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.014	0.014	0.015





## **OIL ANALYSIS REPORT**
















I LOID I HOI LI	TILO	memou			History	HISTOLYZ
Visc @ 40°C	cSt	ASTM D445	65.6	66.7	67.0	69.3

SAIVIFLE IIVIAGES	memou		
		Co.	



Color









Certificate 12367

Laboratory Sample No. Lab Number

: 06177262 Unique Number : 11023315

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : USP0011432 Received : 13 May 2024 **Tested** 

Test Package : IND 2

: 14 May 2024 : 15 May 2024 - Doug Bogart Diagnosed

US 76117 Contact: Service Manager

3900 MEACHAM BLVD

HALTOM CITY, TX

**TYSON - HALTOM CITY PROC** 

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: