


OIL ANALYSIS REPORT

Area 90 Machine Id [90] A90 V114

Center Agitator Gearbox

HIGH PERFORMANCE LUBRICANTS GEAR LIFE 220 (5 GAL)





Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

	•					
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		HPL0004406	HPL0001844	HPL0000057
Sample Date		Client Info		07 May 2024	06 Apr 2023	23 Feb 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		10000	3500	12392
Oil Changed		Client Info		Not Changd	Changed	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>150	17	25	13
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>10	0	0	1
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	2	0	2
Lead	ppm	ASTM D5185m	>100	<1	0	<1
Copper	ppm	ASTM D5185m	>50	<1	0	<1
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m	>5			<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<1	0	1
Barium	ppm	ASTM D5185m		2	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		<1	<1	0
Calcium	ppm	ASTM D5185m		17	17	16
Phosphorus	ppm	ASTM D5185m		230	144	225
Zinc	ppm	ASTM D5185m		105	83	135
Sulfur	ppm	ASTM D5185m		30777	21033	15080
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	3	2	3
Sodium	ppm	ASTM D5185m		10	8	6
Potassium	ppm	ASTM D5185m	>20	2	0	2
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.75	0.24	0.13	0.34



OIL ANALYSIS REPORT

Visc @ 40°C




VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	ΓIES	method	limit/base	current	history1	historv2

	y @ +0 C			
250 T Abnormal				
1				
240				
230				
Base 220				
220				
220				
3				
210-				
200 Abnormal				<u> </u>
ī				
190				
0.	=	2	52	95
Jan 14/2	Mar3/2	3/2	Apr6/2	May7/24
Ė	TO .	Feb23/7	<u> </u>	al
- P	<	100	<<	≥


SAMPLE IMAGES	method	limit/base	current	history1	history2
Color			no image	no image	no image
Bottom			no image	no image	no image
ODADUO					

218




cSt


ASTM D445 225





219

217













Certificate 12367

Laboratory Sample No. Lab Number : 06177359 Unique Number : 11023412

Test Package : MOB 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : HPL0004406

Received **Tested**

Diagnosed

: 13 May 2024 : 14 May 2024 : 14 May 2024 - Wes Davis

KENSING 2525 S KENSINGTON RD KANKAKEE, IL US 60901

Contact: TIM HUBERT timothy.hubert@kensingsolutions.com T: (815)939-8918

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: x: