




OIL ANALYSIS REPORT

Machine Id
Hancock CAT 3 (S/N 3RC00176)
 Component
Biogas Engine
 Fluid
CHEVRON HDAX 9500 GAS ENGINE OIL 40 (95 GAL)

Sample Rating Trend



DIAGNOSIS

▲ Recommendation

We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

▲ Wear

The tin level is severe.

▲ Contamination

Elemental level of silicon (Si) above normal.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0898190	WC0898187	WC0898162
Sample Date	Client Info		09 May 2024	02 May 2024	26 Apr 2024
Machine Age	hrs	Client Info	75566	75398	75212
Oil Age	hrs	Client Info	517	349	163
Oil Changed	Client Info		Not Chngd	Not Chngd	Not Chngd
Sample Status			SEVERE	ABNORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method	>.11	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >15	3	2	2
Chromium	ppm	ASTM D5185m >4	<1	<1	0
Nickel	ppm	ASTM D5185m	<1	0	0
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >6	4	2	1
Lead	ppm	ASTM D5185m >9	2	1	1
Copper	ppm	ASTM D5185m >6	5	2	1
Tin	ppm	ASTM D5185m >4	▲ 8	▲ 4	3
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	93	35	23
Barium	ppm	ASTM D5185m	2	0	0
Molybdenum	ppm	ASTM D5185m	9	6	5
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	41	24	23
Calcium	ppm	ASTM D5185m	2796	1776	1779
Phosphorus	ppm	ASTM D5185m	603	343	301
Zinc	ppm	ASTM D5185m	688	402	367
Sulfur	ppm	ASTM D5185m	5335	3043	2724

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >181	▲ 188	110	77
Sodium	ppm	ASTM D5185m >21	0	0	<1
Potassium	ppm	ASTM D5185m >20	4	3	<1

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	0.1	0
Nitration	Abs/cm	*ASTM D7624	6.6	6.7	6.1
Sulfation	Abs/.1mm	*ASTM D7415	21.1	19.9	17.8


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	15.7	14.3	11.3
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	1.38	1.22	0.76
Base Number (BN)	mg KOH/g	ASTM D2896 5.4	3.80	4.41	4.52




OIL ANALYSIS REPORT

▲ Non-ferrous Metals



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.11	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


● FT-IR (Direct Trend)




FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.4	14.2	13.7

GRAPHS


Acid Number




Acid Number




Base Number




Iron (ppm)




Aluminum (ppm)




Copper (ppm)




Viscosity @ 100°C




Lead (ppm)




Chromium (ppm)



▲ Silicon (ppm)



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0898190

Lab Number : 06177374

Unique Number : 11023427

Test Package : MOB 2

Received : 13 May 2024

Tested : 14 May 2024

Diagnosed : 15 May 2024 - Don Baldrige

EDL NA Recips-Hancock County

HANCOCK COUNTY POWER STATION, 3574 TOWNSHIP ROAD 142

FINDLAY, OH

US 45840

Contact: TIM CUSICK

tim.cusick@edlenergy.com

T:

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)