

COOLANT REPORT

NORMAL





COLORADO/443

Radiator Coolant

CATERPILLAR ELC (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The fluid is suitable for further service.

Wear

All metal levels are normal indicating no corrosion in the cooling system.

Contamination

There is no indication of any contamination in the coolant.

Fluid Condition

Carboxylate test failed. Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

143 ORADO^4	43]					
GAL)			Dec2023	AprŽ024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	histo
Sample Number		Client Info		WC0883903	WC0859586	
Sample Date		Client Info		05 Apr 2024	12 Dec 2023	
Machine Age	hrs	Client Info		497	376	
Oil Age	hrs	Client Info		497	376	
Oil Changed		Client Info		Not Changd	Not Changd	
Sample Status				NORMAL	NORMAL	
CONTAMINATIO	N	method	limit/base	current	history1	histo
Water		WC Method		NEG	NEG	
PHYSICAL TEST F	RESULTS	method	limit/base	current	history1	histo

Sample Rating Trend

CONTINUINATION						
Water		WC Method		NEG	NEG	
PHYSICAL TEST R	RESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.066	1.067	
рН	Scale 0-14	ASTM D1287		7.88	8.06	
Nitrites	ppm	AP-053:2009		636	748	
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		49.0	49.3	
Freezing Point	°F	ASTM D3321		-33	-33	
Total Dissolved Solids				325.0	414.5	
Carboxylate				fail	fail	
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130	0	14	11	
Phosphorus	ppm	ASTM D6130	0	128	133	
Boron	ppm	ASTM D6130	0	0	0	

Silicon	ppm	ASTM D6130	0	14	11	
Phosphorus	ppm	ASTM D6130	0	128	133	
Boron	ppm	ASTM D6130	0	0	0	
Molybdenum	ppm	ASTM D6130	950	568	571	
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130		0	0	
Aluminum	ppm	ASTM D6130		<1	<1	
Copper	ppm	ASTM D6130		<1	<1	
Lead	ppm	ASTM D6130		<1	<1	
Tin	ppm	ASTM D6130		0	2	
Zinc	ppm	ASTM D6130		0	1	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		25	18	
CARRIER SALTS	;	method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130		4197	3867	
Potassium	ppm	ASTM D6130		499	570	
			11 1. //			

0

ASTM D6130

ASTM D6130

ppm


ppm


Calcium

Magnesium



COOLANT REPORT









Certificate 12367

Laboratory Sample No.

Lab Number : 06177656 Unique Number : 11023709

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0883903

Received **Tested** Diagnosed

: 13 May 2024 : 16 May 2024 : 16 May 2024 - Angela Borella Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType, ICP)

SHERWOOD CONSTRUCTION CO INC 3219 WEST MAY ST WICHITA, KS US 67213 Contact: BILL ORCUTT

william.orcutt@wildcat.net

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Submitted By: BRANDEN JAQUIAS

T:

F: