


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

8219071 (S/N 1572) Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

וט	Δ		u 🗪		
	\sim	чι	\sim	\sim	\cdot

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Ju	2022	Aug2023 May20	24	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017338	KCPA004800	KCP49617
Sample Date		Client Info		03 May 2024	10 Aug 2023	22 Jun 2022
Machine Age	hrs	Client Info		12044	8853	3467
Oil Age	hrs	Client Info		3191	0	3467
Oil Changed		Client Info		Not Changd	N/A	Changed
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	1	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	2	<1	<1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	5	5	2
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	1
Barium	ppm	ASTM D5185m	90	1	0	12
Molybdenum	ppm	ASTM D5185m		<1	<1	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	90	15	11	30
Calcium	ppm	ASTM D5185m	2	4	2	1
Phosphorus	ppm	ASTM D5185m		8	4	7
Zinc	ppm	ASTM D5185m		12	0	7
Sulfur	ppm	ASTM D5185m		21922	22228	18157
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		0	4	2
Potassium	ppm	ASTM D5185m	>20	2	2	5
Water	%	ASTM D6304	>0.05	0.011	0.009	0.022
ppm Water	ppm	ASTM D6304	>500	113	96.2	225.1
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2126	226	240
Particles >6µm		ASTM D7647	>1300	481	91	42
Particles >14µm		ASTM D7647	>80	21	8	5
Particles >21µm		ASTM D7647	>20	7	2	2
Particles >38µm		ASTM D7647	>4	1	0	1
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/12	15/14/10	15/13/10
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.43	0.38	0.43



OIL ANALYSIS REPORT





Certificate 12367

Laboratory

Sample No. Lab Number

: 06177688 Unique Number : 11023741

: KCPA017338

Received **Tested**

: 13 May 2024 Diagnosed Test Package : IND 2 (Additional Tests: KF, PrtCount)

: 14 May 2024 : 15 May 2024 - Don Baldridge

8701 N HARRISON SHAWNEE, OK US 774804

Contact: A. BOONE ABOONE@ADVANCEDTECH.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: