


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# 5480908 (S/N 1021)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.


#### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		712010 11012	017 10012010 0002010		002023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC129924	KC126791	KC111312
Sample Date		Client Info		10 Apr 2024	29 Jan 2024	23 Oct 2023
Machine Age	hrs	Client Info		54561	53885	52879
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	N/A	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	0
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	0	0
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	9	<1	3
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	8	8	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	90	65	71	6
Calcium	ppm	ASTM D5185m	2	6	2	0
Phosphorus	ppm	ASTM D5185m		8	4	0
Zinc	ppm	ASTM D5185m		9	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		16	17	7
Potassium	ppm	ASTM D5185m	>20	4	<1	2
Water	%	ASTM D6304	>0.05	0.045	0.017	<b>△</b> 0.248
ppm Water	ppm	ASTM D6304	>500	457	173	<u>^</u> 2480
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		149916	9790	274
Particles >6µm		ASTM D7647	>1300	<b>△</b> 50783	<u>▲</u> 3253	70
Particles >14µm		ASTM D7647	>80	<b>△</b> 3697	<b>▲</b> 331	10
Particles >21µm		ASTM D7647	>20	<b>923</b>	<b>▲</b> 86	3
Particles >38μm		ASTM D7647	>4	<u> </u>	<u>^</u> 6	0
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>4</u> 24/23/19	<b>2</b> 0/19/16	15/13/10
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.33	0.37	0.24





## **OIL ANALYSIS REPORT**











VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.05	NEG	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	43.8	44.5	43.7


method

Color



SAMPLE IMAGES









Certificate 12367

Laboratory Sample No. : KC129924 Lab Number : 06177703 Unique Number : 11023756

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 13 May 2024 **Tested** : 14 May 2024

Diagnosed : 15 May 2024 - Don Baldridge

**CHECKER DISTRIBUTORS** 

400 W DUSSELL DR MAUMEE, OH

US 43537 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: