


# **OIL ANALYSIS REPORT**

**ULTRA COOLANT INGERSOLL RAND MOX1005426 - ADVANEX AMERICAS** Component





## Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

## Contamination

There is no indication of any contamination in the oil.


# **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06177794		
Sample Date		Client Info		12 Apr 2024		
Machine Age	hrs	Client Info		17431		
Oil Age	hrs	Client Info		4000		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	2		
Lead	ppm	ASTM D5185m	>25	1		
Copper	ppm	ASTM D5185m	>50	2		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	500	607		
Molybdenum	ppm	ASTM D5185m	0	<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	0	2		
Calcium	ppm	ASTM D5185m	0	8		
Phosphorus	ppm	ASTM D5185m	20	<1		
Zinc	ppm	ASTM D5185m	0	6		
Sulfur	ppm	ASTM D5185m	200	229		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3		
Sodium	ppm	ASTM D5185m		64		
Potassium	ppm	ASTM D5185m	>20	8		
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.53		



# **OIL ANALYSIS REPORT**




VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
<b>Emulsified Water</b>	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
	TIEC	ام مالم مور	lineit/lenen		الاستعادات	history O
FLUID PROPERTIES		method	limit/base	current	history1	history2


viso @ 40°C	oSt.	ASTM D445	10.1	50.8	
Visc @ 40°C	CSI	ASTIVI D445	49.4	50.6	 


O == 10:=0	 			
Color		ACQ Book Mone Curro Mone Curro Mone Curro Mone Curro Mone Curro Mone Curro Mone Curro Mone Curro Mone Curro Mone Curro Mone Curro Mone Curro Mone Curro Mone Mone Mone Mone Mone Mone Mone Mon	no image	no image
Bottom			no image	no image
CDADUC				

## GRAPHS



10	Non-ferrous Metals
8	copper
mdd 4	enanananan (ead
H 4-	
2	
	Apri 2/24 -
	Арі









Certificate 12367

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 **Sample No.** : UCH06177794 Lab Number : 06177794 Unique Number : 11029120

Test Package : IND 2

Received Tested

: 13 May 2024 : 14 May 2024

Diagnosed : 15 May 2024 - Sean Felton

**JOHN BOUCHARD & SONS** 1024 HARRISON ST. NASHVILLE, TN US 37203

Contact: STEVE SANDERS Steve.sanders@jbouchard.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: (865)544-1400