


OIL ANALYSIS REPORT

Sample Rating Trend



SEDIMENT



Area
Paper Cup Machines
 Machine Id
PMC 1003 POS-421 (S/N 189465)
 Component
Circulating System
 Fluid
SUMMIT Syngear SH-1032 320 (85 GAL)

DIAGNOSIS

- Recommendation**
 We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.
- Wear**
 All component wear rates are normal.
- Contamination**
 Appearance is hazy. There is a moderate amount of visible silt present in the sample.
- Fluid Condition**
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO50002468	TO50002183	TO50001953
Sample Date	Client Info	07 May 2024	13 Mar 2024	27 Jan 2024
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	Filtered
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184	31	18	21
Iron	ppm	13	12	14
Chromium	ppm	<1	<1	<1
Nickel	ppm	0	9	9
Titanium	ppm	0	<1	<1
Silver	ppm	0	<1	0
Aluminum	ppm	<1	2	1
Lead	ppm	0	2	<1
Copper	ppm	2	2	4
Tin	ppm	<1	<1	<1
Vanadium	ppm	0	<1	0
Cadmium	ppm	0	<1	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	67	48	66
Barium	ppm	<1	0	0
Molybdenum	ppm	0	0	0
Manganese	ppm	<1	<1	<1
Magnesium	ppm	0	0	0
Calcium	ppm	<1	2	23
Phosphorus	ppm	453	414	466
Zinc	ppm	0	0	16
Sulfur	ppm	7029	6601	6471

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	6425	4118	4645
Sodium	ppm	<1	2	2
Potassium	ppm	0	1	0
Water	%	0.018	0.012	0.015
ppm Water	ppm	181	126	158






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>1300	---	▲ 3097
Particles >6µm	ASTM D7647	>320	---	▲ 1687
Particles >14µm	ASTM D7647	>80	---	▲ 287
Particles >21µm	ASTM D7647	>20	---	▲ 97
Particles >38µm	ASTM D7647	>4	---	▲ 15
Particles >71µm	ASTM D7647	>3	---	▲ 2
Oil Cleanliness	ISO 4406 (c)	>17/15/13	---	▲ 19/18/15

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	0.69	0.70	0.88


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	▲ MODER	▲ MODER	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	HAZY	HAZY	MILKY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	326	316	318
Visc @ 100°C	cSt	ASTM D445	33.4	31.8	31.3
Viscosity Index (VI)	Scale	ASTM D2270	145	139	136

SAMPLE IMAGES



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO50002468 **Received** : 14 May 2024
Lab Number : 06178732 **Tested** : 20 May 2024
Unique Number : 11030058 **Diagnosed** : 20 May 2024 - Don Baldrige
Test Package : IND 2 (Additional Tests: KF, KV100, PQ, PrtCount, VI)

DART CONTAINER CORPORATION
 4444 W LEADBETTER DR
 DALLAS, TX
 US 75236
 Contact: YON PALOMINO
 yon.palomino@dart.biz
 T: (214)775-5673
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)