




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Machine Id
B17797 - AMMONIA COMPRESSOR 2 (S/N 17010 AS RCB)
 Component
Refrigeration Compressor
 Fluid
CHEVRON CAPELLA OIL WF 68 (14 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | WC0907900 | WC0872396 | WC0736173 |
| Sample Date | Client Info | | 24 Apr 2024 | 18 Jan 2024 | 16 Oct 2023 |
| Machine Age | hrs | Client Info | 10 | 0 | 0 |
| Oil Age | hrs | Client Info | 10 | 0 | 0 |
| Oil Changed | Client Info | | Not Changed | N/A | N/A |
| Sample Status | | | NORMAL | ABNORMAL | NORMAL |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|----------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m >8 | <1 | <1 | <1 |
| Chromium | ppm | ASTM D5185m >2 | <1 | 0 | <1 |
| Nickel | ppm | ASTM D5185m | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | <1 | 0 | 0 |
| Silver | ppm | ASTM D5185m >2 | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m >3 | 1 | 0 | 2 |
| Lead | ppm | ASTM D5185m >2 | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185m >8 | <1 | 0 | <1 |
| Tin | ppm | ASTM D5185m >4 | <1 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | <1 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | <1 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|---------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | 0 | 0 | 3 |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | <1 |
| Manganese | ppm | ASTM D5185m | 0 | 0 | 0 |
| Magnesium | ppm | ASTM D5185m 0 | <1 | 0 | 0 |
| Calcium | ppm | ASTM D5185m | 3 | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | 0 | 3 | 4 |
| Zinc | ppm | ASTM D5185m | 0 | 0 | 0 |
| Sulfur | ppm | ASTM D5185m | 153 | 323 | 155 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|------------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m >15 | 0 | 0 | 0 |
| Sodium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Potassium | ppm | ASTM D5185m >20 | 1 | 0 | 1 |
| Water | % | ASTM D6304 >0.01 | 0.001 | 0.00 | 0.003 |
| ppm Water | ppm | ASTM D6304 >100 | 14 | 0 | 28.2 |

FLUID CLEANLINESS






| | method | limit/base | current | history1 | history2 |
|-----------------|--------------|------------|-----------------|------------|----------|
| Particles >4µm | ASTM D7647 | >10000 | 5236 | ▲ 24449 | 4721 |
| Particles >6µm | ASTM D7647 | >2500 | 878 | ▲ 6068 | 1164 |
| Particles >14µm | ASTM D7647 | >320 | 24 | ▲ 497 | 61 |
| Particles >21µm | ASTM D7647 | >80 | 5 | ▲ 146 | 13 |
| Particles >38µm | ASTM D7647 | >20 | 0 | 6 | 0 |
| Particles >71µm | ASTM D7647 | >4 | 0 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >20/18/15 | 20/17/12 | ▲ 22/20/16 | 19/17/13 |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|------------|--------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D974 | 0.014 | 0.046 | 0.013 |




OIL ANALYSIS REPORT







| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.01 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 64.0 | 68.1 | 79.0 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0907900 **Received** : 14 May 2024
Lab Number : 06178838 **Tested** : 16 May 2024
Unique Number : 11030164 **Diagnosed** : 16 May 2024 - Don Baldrige
Test Package : IND 2 (Additional Tests: PrtCount)

HORMEL FOODS-BELOIT
 3000 KENNEDY DRIVE
 BELOIT, WI
 US 53511
 Contact: Craig Bennett
 cabennett@hormel.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (608)365-8322