


OIL ANALYSIS REPORT

DELTA DPA **KAESER 2763 - EVERGREEN PACK INC**

Component Compressor

ULTRACHEM CHEMLUBE 228 (12 GAL)





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
|------------------|----------|-------------|------------|-------------|-------------|-------------|
| Sample Number | | Client Info | | WC0924343 | UCH05777583 | UCH05468886 |
| Sample Date | | Client Info | | 01 May 2024 | 23 Jan 2023 | 25 Jan 2022 |
| Machine Age | hrs | Client Info | | 13662 | 11185 | 8821 |
| Oil Age | hrs | Client Info | | 2478 | 4321 | 2178 |
| Oil Changed | | Client Info | | Changed | Changed | Changed |
| Sample Status | | | | NORMAL | NORMAL | NORMAL |
| CONTAMINATION | V | method | limit/base | current | history1 | history2 |
| Water | | WC Method | >0.05 | NEG | NEG | NEG |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | 0 | 0 | 0 |
| Chromium | ppm | ASTM D5185m | >10 | <1 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >3 | <1 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | >3 | <1 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >2 | 0 | <1 | 0 |
| Aluminum | ppm | ASTM D5185m | >10 | 2 | <1 | 0 |
| Lead | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185m | >50 | 1 | 1 | <1 |
| Tin | ppm | ASTM D5185m | >10 | <1 | 0 | <1 |
| Antimony | ppm | ASTM D5185m | | | | 0 |
| Vanadium | ppm | ASTM D5185m | | <1 | <1 | 0 |
| Cadmium | ppm | ASTM D5185m | | <1 | 0 | 0 |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | 1.5 | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | 0 | <1 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | 0 | <1 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | 0.3 | 0 | <1 | 0 |
| Magnesium | ppm | ASTM D5185m | 0 | <1 | 6 | 0 |
| Calcium | ppm | ASTM D5185m | 0 | 3 | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | 406 | 225 | 202 | 237 |
| Zinc | ppm | ASTM D5185m | 0 | 8 | 20 | 0 |
| Sulfur | ppm | ASTM D5185m | 1283 | 1056 | 860 | 425 |
| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | <1 | <1 | <1 |
| Sodium | ppm | ASTM D5185m | | 0 | <1 | 0 |
| Potassium | ppm | ASTM D5185m | >20 | 1 | 0 | 0 |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.463 | 0.076 | 0.139 | 0.113 |



OIL ANALYSIS REPORT



| VISUAL | | method | | | | history2 |
|-------------------------|--------|-----------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG | NEG |
| FLUID PROPERT | IES | method | limit/base | current | history1 | history2 |
| Visc @ 40°C | cSt | ASTM D445 | 47.9 | 45.1 | 44.8 | 45.5 |
| SAMPLE IMAGES | 3 | method | limit/base | current | history1 | history2 |
| Color | | | | | | |







Certificate 12367

Laboratory Sample No.

: WC0924343 Lab Number : 06178918

Unique Number : 11030244 Test Package : IND 2

Bottom

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 14 May 2024

Tested : 16 May 2024 Diagnosed

: 16 May 2024 - Don Baldridge

DELTA INDUSTRIES - CEDAR RAPIDS 6540 4TH ST SW UNIT A

CEDAR RAPIDS, IA US 52404

Contact: MICHAEL FERRIS wearcheck@deltaind.net

T: (319)862-2500 F: (319)862-2501

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: UCDELCED [WUSCAR] 06178918 (Generated: 05/16/2024 13:11:58) Rev: 1

Contact/Location: MICHAEL FERRIS - UCDELCED