

## **OIL ANALYSIS REPORT**

Sample Rating Trend

## NORMAL

### Area PG-46 [SO-287841] Machine Id PNEUTECH AK100021194 - MP SYSTEMS

Component Compressor

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0001776		
Sample Date		Client Info		08 May 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		1102		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
				-		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	2		
Lead	ppm	ASTM D5185m	>25	<1		
Copper	ppm	ASTM D5185m	>50	1		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		<1		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		4		
Calcium	ppm	ASTM D5185m		6		
Phosphorus	ppm	ASTM D5185m		756		
Zinc	ppm	ASTM D5185m		80		
Sulfur	ppm	ASTM D5185m		129		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	12		
Sodium	ppm	ASTM D5185m		7		
Potassium	ppm	ASTM D5185m	>20	6		
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.19		



0.00 May8/24

# **OIL ANALYSIS REPORT**



	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
May8/24	Appearance	scalar	*Visual	NORML	NORML		
2	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
	Free Water	scalar	*Visual		NEG		
	FLUID PROPERT	TIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445		46.7		
	SAMPLE IMAGES	S	method	limit/base	current	history1	history2
May8/24	Color					no image	no image
	Bottom					no image	no image
	Non-ferrous Metal			May024			
	b d d d d d d d d d d d d d d d d d d d						
	2 0 472 Ware W			May8/24			
				May8/24 +	Acid Number		
	Viscosity @ 40°C			0.00 00.0 00.0 00.0 00.0 00.0 00.0 00.			
Laboratory Sample No. Lab Number Unique Number Test Package discuss this sample report, Denotes test methods that a	Viscosity @ 40°C	1 Madiso Recei Teste Diagn	n Ave., Cary ved : 14 d : 15 iosed : 16 00-237-1365	, NC 27513 May 2024 May 2024 - Don	F200/eW	BUF	JAMICS - (MN JDICIAL ROAI RNSVILLE, MI US 5530 ervice Manage

Contact/Location: Service Manager - UCFLUBUR Page 2 of 2