



# OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION

Machine Id  
**4549-2**  
 Component  
**2 Gearbox**  
 Fluid  
**OPTIGEAR RMO 150 (--- GAL)**

## DIAGNOSIS

### Recommendation

The oil is near the end of its useful service life, recommend schedule an oil change. Resample at the next service interval to monitor. Please note that this is a corrected copy for diagnostic comment updates per supplied limits.

### Wear

The lead level is abnormal. All other component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is above the recommended limit.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0920082</b>	---	---
Sample Date	Client Info		<b>24 Apr 2024</b>	---	---
Machine Age	mls	Client Info	<b>10380</b>	---	---
Oil Age	mls	Client Info	<b>10380</b>	---	---
Oil Changed	Client Info		<b>Not Chngd</b>	---	---
Sample Status			<b>ABNORMAL</b>	---	---

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.2	<b>NEG</b>	---	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >200	<b>39</b>	---	---
Chromium	ppm	ASTM D5185m >10	<b>&lt;1</b>	---	---
Nickel	ppm	ASTM D5185m >10	<b>&lt;1</b>	---	---
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	---	---
Silver	ppm	ASTM D5185m	<b>0</b>	---	---
Aluminum	ppm	ASTM D5185m >25	<b>10</b>	---	---
Lead	ppm	ASTM D5185m >50	<b>▲ 9</b>	---	---
Copper	ppm	ASTM D5185m >200	<b>81</b>	---	---
Tin	ppm	ASTM D5185m >10	<b>&lt;1</b>	---	---
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	---	---
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	---	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>7</b>	---	---
Barium	ppm	ASTM D5185m	<b>30</b>	---	---
Molybdenum	ppm	ASTM D5185m	<b>917</b>	---	---
Manganese	ppm	ASTM D5185m	<b>1</b>	---	---
Magnesium	ppm	ASTM D5185m	<b>21</b>	---	---
Calcium	ppm	ASTM D5185m	<b>126</b>	---	---
Phosphorus	ppm	ASTM D5185m	<b>1886</b>	---	---
Zinc	ppm	ASTM D5185m	<b>348</b>	---	---
Sulfur	ppm	ASTM D5185m	<b>20026</b>	---	---

## CONTAMINANTS




	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>13</b>	---	---
Sodium	ppm	ASTM D5185m	<b>6</b>	---	---
Potassium	ppm	ASTM D5185m >20	<b>3</b>	---	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>▲ 2.52</b>	---	---



# OIL ANALYSIS REPORT











VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	LIGHT	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.2	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	157	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color				no image	no image	no image
Bottom				no image	no image	no image

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0920082  
**Lab Number** : 06178974  
**Unique Number** : 11030300  
**Test Package** : MOB 2

**Received** : 14 May 2024  
**Tested** : 15 May 2024  
**Diagnosed** : 20 Jun 2024 - Doug Bogart

**ALSTOM C/O NEW JERSEY TRANSIT**  
 1148 NEWARK TURNPIKE  
 KEARNY, NJ  
 US 07032

Contact: DAVE GILBERT  
 david.gilbert@alstomgroup.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (973)277-0826