




# OIL ANALYSIS REPORT

Sample Rating Trend



**DIRT**



Machine Id  
**HBKM01BE**  
 Component  
**Biogas Engine**  
 Fluid  
**SHELL MYSELLA S5 S (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition. ( Customer Sample Comment: Top Up Amount: 30 GAL )

### ▲ Wear

The tin level is abnormal.

### ▲ Contamination

Elemental level of silicon (Si) above normal.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0775173</b>	WC0775182	WC0775178
Sample Date	Client Info		<b>10 May 2024</b>	29 Apr 2024	25 Apr 2024
Machine Age	hrs	Client Info	<b>109935</b>	109759	109663
Oil Age	hrs	Client Info	<b>545</b>	369	273
Oil Changed	Client Info		<b>Oil Added</b>	Oil Added	Oil Added
Sample Status			<b>SEVERE</b>	ABNORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Water	WC Method		<b>NEG</b>	NEG	NEG
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >14	<b>10</b>	7	7
Chromium	ppm	ASTM D5185m >3	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >5	<b>4</b>	3	3
Lead	ppm	ASTM D5185m >8	<b>0</b>	0	<1
Copper	ppm	ASTM D5185m >5	<b>2</b>	▲ 5	<1
Tin	ppm	ASTM D5185m >3	▲ <b>4</b>	▲ 4	2
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	7	6
Barium	ppm	ASTM D5185m	<b>0</b>	<1	0
Molybdenum	ppm	ASTM D5185m	<b>8</b>	8	7
Manganese	ppm	ASTM D5185m	<b>0</b>	1	0
Magnesium	ppm	ASTM D5185m	<b>24</b>	24	24
Calcium	ppm	ASTM D5185m	<b>1723</b>	1526	1537
Phosphorus	ppm	ASTM D5185m 300	<b>352</b>	337	341
Zinc	ppm	ASTM D5185m	<b>441</b>	413	424
Sulfur	ppm	ASTM D5185m	<b>3558</b>	3321	3435

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >180	▲ <b>236</b>	158	126
Sodium	ppm	ASTM D5185m >20	<b>3</b>	2	1
Potassium	ppm	ASTM D5185m >20	<b>0</b>	0	0

## INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0</b>	0	0
Nitration	Abs/cm	*ASTM D7624	<b>4.7</b>	4.4	4.3
Sulfation	Abs/.1mm	*ASTM D7415	<b>21.4</b>	19.3	18.8


## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	<b>13.5</b>	12.3	11.8
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>1.20</b>	0.86	0.67
Base Number (BN)	mg KOH/g	ASTM D2896 5.3	<b>3.03</b>	3.78	3.72




# OIL ANALYSIS REPORT


## Non-ferrous Metals




## FT-IR (Direct Trend)




## Acid Number



## Acid Number



## Base Number




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.5	13.3	13.2

## GRAPHS


### Iron (ppm)




### Aluminum (ppm)




### Copper (ppm)




### Viscosity @ 100°C




### Lead (ppm)




### Chromium (ppm)



### Silicon (ppm)



### Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : WC0775173  
 Lab Number : 06178991  
 Unique Number : 11030317  
 Test Package : MOB 2

Received : 14 May 2024  
 Tested : 15 May 2024  
 Diagnosed : 16 May 2024 - Don Baldrige

**EDL NA Recips-Honeybrook**  
 Honey Brook Powerstation, 481 S. Churchtown Road  
 Narvon, PA  
 US 17555-9574  
 Contact: Christian Adames  
 Christian.Adames@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)