




# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

## HOTLINE/SCALPER

Machine Id

## WAY LUBE RESERVOIR 1401-001-1520

Component

### Hydraulic System

Fluid

### CITGO SLIDERITE 220 (700 GAL)

#### DIAGNOSIS

##### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

##### Wear

All component wear rates are normal.

##### Contamination

There is a high amount of particulates present in the oil.

##### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

#### SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KFS0004856</b>	KFS0004834	KFS0003804
Sample Date	Client Info	<b>11 Apr 2024</b>	16 Feb 2024	01 Aug 2023
Machine Age	hrs	<b>0</b>	0	0
Oil Age	hrs	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

#### CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.05	<b>NEG</b>	NEG	NEG

#### WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >20	<b>5</b>	0	7
Chromium	ppm ASTM D5185m >20	<b>0</b>	0	0
Nickel	ppm ASTM D5185m >20	<b>&lt;1</b>	<1	0
Titanium	ppm ASTM D5185m	<b>0</b>	0	<1
Silver	ppm ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm ASTM D5185m >20	<b>6</b>	<1	4
Lead	ppm ASTM D5185m >20	<b>0</b>	0	0
Copper	ppm ASTM D5185m >20	<b>2</b>	0	3
Tin	ppm ASTM D5185m >20	<b>&lt;1</b>	3	<1
Vanadium	ppm ASTM D5185m	<b>0</b>	0	<1
Cadmium	ppm ASTM D5185m	<b>0</b>	0	0

#### ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	<b>0</b>	0	0
Barium	ppm ASTM D5185m	<b>0</b>	1	<1
Molybdenum	ppm ASTM D5185m	<b>0</b>	0	0
Manganese	ppm ASTM D5185m	<b>&lt;1</b>	0	<1
Magnesium	ppm ASTM D5185m	<b>3</b>	2	7
Calcium	ppm ASTM D5185m	<b>2</b>	6	2
Phosphorus	ppm ASTM D5185m	<b>11</b>	10	27
Zinc	ppm ASTM D5185m	<b>0</b>	10	24
Sulfur	ppm ASTM D5185m	<b>3611</b>	3001	3669

#### CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >15	<b>2</b>	1	1
Sodium	ppm ASTM D5185m	<b>0</b>	0	<1
Potassium	ppm ASTM D5185m >20	<b>2</b>	0	1





#### FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	<b>▲ 324640</b>	---	---
Particles >6µm	ASTM D7647 >1300	<b>▲ 156026</b>	---	---
Particles >14µm	ASTM D7647 >160	<b>▲ 9030</b>	---	---
Particles >21µm	ASTM D7647 >40	<b>▲ 1610</b>	---	---
Particles >38µm	ASTM D7647 >10	<b>▲ 26</b>	---	---
Particles >71µm	ASTM D7647 >3	<b>2</b>	---	---
Oil Cleanliness	ISO 4406 (c) >19/17/14	<b>▲ 26/24/20</b>	---	---

#### FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045	<b>0.069</b>	0.06	0.16


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	▲ HEAVY	▲ MODER
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 222	201	▲ 188	200

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KFS0004856      **Received** : 14 May 2024  
**Lab Number** : 06179312      **Tested** : 16 May 2024  
**Unique Number** : 11030638      **Diagnosed** : 16 May 2024 - Don Baldrige  
**Test Package** : IND 2

**CONSTELLIUM**  
 4805 SECOND STREET  
 MUSCLE SHOALS, AL  
 US 35661  
 Contact: Joel Even  
 joel.even@constellium.com  
 T: (256)740-7490  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)