




OIL ANALYSIS REPORT

Sample Rating Trend



DIRT



Area

CAST HOUSE/CRANES

Machine Id

92 CENTER BRIDGE GEARBOX 1015-M92-2000

Component

Gearbox

Fluid

CITGO COMPOUND EP 320 (15 GAL)

DIAGNOSIS

Recommendation

We advise that you check all areas where dirt can enter the system. We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition.

Wear

An increase in the iron level is noted. Gear wear is indicated.

Contamination

There is a high amount of particulates present in the oil. Elemental levels of silicon (Si) and aluminum (Al) indicate alumina-silicate (coarse dirt) ingress.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KFS0004613	KFS0004920	KFS0003316
Sample Date	Client Info	19 Apr 2024	15 Dec 2023	03 Jul 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.2	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >200	▲ 345	82	169
Chromium	ppm ASTM D5185m >15	2	<1	<1
Nickel	ppm ASTM D5185m >15	<1	<1	<1
Titanium	ppm ASTM D5185m	<1	<1	0
Silver	ppm ASTM D5185m	0	0	0
Aluminum	ppm ASTM D5185m >25	● 75	23	43
Lead	ppm ASTM D5185m >100	0	0	0
Copper	ppm ASTM D5185m >200	3	0	3
Tin	ppm ASTM D5185m >25	<1	0	0
Vanadium	ppm ASTM D5185m	0	0	<1
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	16	<1	4
Barium	ppm ASTM D5185m	<1	0	0
Molybdenum	ppm ASTM D5185m	2	0	1
Manganese	ppm ASTM D5185m	6	2	2
Magnesium	ppm ASTM D5185m	7	4	1
Calcium	ppm ASTM D5185m	39	12	9
Phosphorus	ppm ASTM D5185m	248	110	259
Zinc	ppm ASTM D5185m	63	10	69
Sulfur	ppm ASTM D5185m	7498	5469	8725

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >50	▲ 57	7	6
Sodium	ppm ASTM D5185m	3	0	0
Potassium	ppm ASTM D5185m >20	5	5	0


FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	▲ 401433	---	▲ 275440
Particles >6µm	ASTM D7647 >5000	▲ 326472	---	▲ 215977
Particles >14µm	ASTM D7647 >640	▲ 79249	---	▲ 26785
Particles >21µm	ASTM D7647 >160	▲ 23126	---	▲ 3619
Particles >38µm	ASTM D7647 >40	▲ 941	---	▲ 51
Particles >71µm	ASTM D7647 >10	▲ 30	---	1
Oil Cleanliness	ISO 4406 (c) >21/19/16	▲ 26/26/23	---	▲ 25/25/22


FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045	0.71	0.46	0.62


▲ Particle Trend




▲ Silicon (ppm)




● Aluminum (ppm)



▲ Silicon (ppm)




● Aluminum (ppm)



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	MODER	NONE
Debris	scalar	*Visual	NONE	NONE	▲ HEAVY
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 314	287	289	● 230

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




GRAPHS


▲ Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KFS0004613 **Received** : 14 May 2024
Lab Number : 06179314 **Tested** : 15 May 2024
Unique Number : 11030640 **Diagnosed** : 16 May 2024 - Don Baldrige
Test Package : IND 2 (Additional Tests: PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

CONSTELLIUM
 4805 SECOND STREET
 MUSCLE SHOALS, AL
 US 35661
 Contact: Randy Nichols
 randall.nichols@constellium.com
 T: (256)386-6956
 F: