








# PROBLEM SUMMARY

Area  
**CAST HOUSE/CRANES**  
 Machine Id  
**92 EAST BRIDGE GEARBOX 1015-M92-1000**  
 Component  
**Gearbox**  
 Fluid  
**CITGO COMPOUND EP 320 (15 GAL)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We recommend that you drain the oil from the component if this has not already been done. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	ABNORMAL
Iron	ppm	ASTM D5185m	>200	▲ <b>565</b>	166	206
Aluminum	ppm	ASTM D5185m	>25	▲ <b>106</b>	▲ 50	20
Silicon	ppm	ASTM D5185m	>50	▲ <b>63</b>	5	34
Particles >4µm		ASTM D7647	>20000	▲ <b>409459</b>	▲ 195947	▲ 291566
Particles >6µm		ASTM D7647	>5000	▲ <b>336555</b>	▲ 118916	▲ 216812
Particles >14µm		ASTM D7647	>640	▲ <b>58618</b>	▲ 5760	▲ 13005
Particles >21µm		ASTM D7647	>160	▲ <b>6412</b>	▲ 961	▲ 316
Oil Cleanliness		ISO 4406 (c)	>21/19/16	▲ <b>26/26/23</b>	▲ 25/24/20	▲ 25/25/21

Customer Id: CONMUSAL  
 Sample No.: KFS0004636  
 Lab Number: 06179316  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Angela Borella +1 800-237-1369  
[angela.borella@wearcheckusa.com](mailto:angela.borella@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	We advise that you inspect for the source(s) of wear.
Change Fluid	---	---	?	We recommend that you drain the oil from the component if this has not already been done.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

ISO



**19 Dec 2023 Diag: Angela Borella**

Check seals and/or filters for points of contaminant entry. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid.

view report



ISO



**03 Jul 2023 Diag: Doug Bogart**

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. Gear wear is indicated. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid.

view report



ISO



**22 Nov 2022 Diag: Wes Davis**

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >14µm are severely high. Particles >6µm are severely high. Oil Cleanliness are severely high. Particles >4µm are severely high. Particles >21µm are abnormally high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report






# OIL ANALYSIS REPORT

Area  
**CAST HOUSE/CRANES**  
 Machine Id  
**92 EAST BRIDGE GEARBOX 1015-M92-1000**  
 Component  
**Gearbox**  
 Fluid  
**CITGO COMPOUND EP 320 (15 GAL)**

Sample Rating Trend



## DIAGNOSIS

### Recommendation

We recommend that you drain the oil from the component if this has not already been done. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

### Wear

Gear wear is indicated.

### Contamination

There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KFS0004636</b>	KFS06041478	KFS0003315
Sample Date	Client Info		<b>19 Apr 2024</b>	19 Dec 2023	03 Jul 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	SEVERE	ABNORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.2	<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>200	<b>▲ 565</b>	166	206
Chromium	ppm	ASTM D5185m	>15	<b>4</b>	<1	2
Nickel	ppm	ASTM D5185m	>15	<b>4</b>	<1	<1
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	0	1
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>25	<b>▲ 106</b>	▲ 50	20
Lead	ppm	ASTM D5185m	>100	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>200	<b>4</b>	4	8
Tin	ppm	ASTM D5185m	>25	<b>&lt;1</b>	0	<1
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>6</b>	5	19
Barium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>3</b>	1	3
Manganese	ppm	ASTM D5185m		<b>7</b>	2	3
Magnesium	ppm	ASTM D5185m		<b>6</b>	2	6
Calcium	ppm	ASTM D5185m		<b>21</b>	9	89
Phosphorus	ppm	ASTM D5185m		<b>272</b>	294	302
Zinc	ppm	ASTM D5185m		<b>95</b>	69	63
Sulfur	ppm	ASTM D5185m		<b>9190</b>	8574	7958

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>50	▲ <b>63</b>	5	34
Sodium	ppm	ASTM D5185m		<b>1</b>	0	2
Potassium	ppm	ASTM D5185m	>20	<b>1</b>	<1	12

## FLUID CLEANLINESS


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ <b>409459</b>	▲ 195947	▲ 291566
Particles >6µm	ASTM D7647	>5000	▲ <b>336555</b>	▲ 118916	▲ 216812
Particles >14µm	ASTM D7647	>640	▲ <b>58618</b>	▲ 5760	▲ 13005
Particles >21µm	ASTM D7647	>160	▲ <b>6412</b>	▲ 961	▲ 316
Particles >38µm	ASTM D7647	>40	<b>42</b>	11	1
Particles >71µm	ASTM D7647	>10	<b>2</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ <b>26/26/23</b>	▲ 25/24/20	▲ 25/25/21

## FLUID DEGRADATION


	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.64</b>	0.58	0.97

# OIL ANALYSIS REPORT


### ▲ Particle Trend




### ▲ Aluminum (ppm)




### ▲ Silicon (ppm)



### ▲ Aluminum (ppm)




### ▲ Silicon (ppm)



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	314	342	319

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




## GRAPHS


### ▲ Ferrous Alloys




### Non-ferrous Metals



### Viscosity @ 40°C



### ▲ Particle Count



### Acid Number



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KFS0004636      **Received** : 14 May 2024  
**Lab Number** : 06179316      **Tested** : 15 May 2024  
**Unique Number** : 11030642      **Diagnosed** : 16 May 2024 - Angela Borella  
**Test Package** : IND 2 ( Additional Tests: PrtCount )

**CONSTELLIUM**  
 4805 SECOND STREET  
 MUSCLE SHOALS, AL  
 US 35661  
 Contact: Randy Nichols  
 randall.nichols@constellium.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)