

PROBLEM SUMMARY

Sample Rating Trend

ISO

Area


CAST HOUSE/CRANES 92 MAIN HOIST GEARBOX 1015-M92-4000


Gearbox

Gearbox

CITGO COMPOUND EP 320 (25 GAL)







RECOMMENDATION

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS									
Sample Status				SEVERE	SEVERE	ABNORMAL			
Iron	ppm	ASTM D5185m	>200	<u>^</u> 220	130	133			
Particles >4µm		ASTM D7647	>20000	381431	▲ 187226	<u>▲</u> 166637			
Particles >6µm		ASTM D7647	>5000	299179	4 91973	△ 59045			
Particles >14µm		ASTM D7647	>640	29794	<u> </u>	<u>▲</u> 1587			
Particles >21µm		ASTM D7647	>160	<u> </u>	240	<u>^</u> 265			
Oil Cleanliness		ISO 4406 (c)	>21/19/16	26/25/22	2 5/24/18	<u>\$\lambda\$</u> 25/23/18			

Customer Id: CONMUSAL Sample No.: KFS0004640 Lab Number: 06179317 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Filter			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.			
Resample			?	We recommend an early resample to monitor this condition.			
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.			
Filter Fluid			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.			

HISTORICAL DIAGNOSIS

15 Dec 2023 Diag: Angela Borella

ISO



Check seals and/or filters for points of contaminant entry. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



ΔR



15 Dec 2023 Diag: Jonathan Hester

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



VISUAL METAL



03 Jul 2023 Diag: Jonathan Hester

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to metal particles present in this sample. The aluminum level is abnormal. Moderate concentration of visible metal present. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






OIL ANALYSIS REPORT

CAST HOUSE/CRANES 92 MAIN HOIST GEARBOX 1015-M92-4000

Gearbox

CITGO COMPOUND EP 320 (25 GAL)





DIAGNOSIS

Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend an early resample to monitor this condition.

Wear

The iron level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KFS0004640	KFS0004921	KFS0004921
Sample Date		Client Info		19 Apr 2024	15 Dec 2023	15 Dec 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	SEVERE	ABNORMAL
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	220	130	133
Chromium	ppm	ASTM D5185m	>15	1	<1	<1
Nickel	ppm	ASTM D5185m	>15	2	<1	0
Titanium	ppm	ASTM D5185m		1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	21	4 6	<u></u> 35
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	8	2	7
Tin	ppm	ASTM D5185m	>25	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		21	5	8
Barium	ppm	ASTM D5185m		1	0	0
Molybdenum	ppm	ASTM D5185m		3	1	2
Manganese	ppm	ASTM D5185m		3	1	1
Magnesium	ppm	ASTM D5185m		10	1	2
Calcium	ppm	ASTM D5185m		67	8	22
Phosphorus	ppm	ASTM D5185m		270	290	403
Zinc Sulfur	ppm	ASTM D5185m ASTM D5185m		50 7119	64	108
	ppm		11 11 11		8551	6070
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm		>50	35	2	7
Sodium	ppm	ASTM D5185m		3	0	2
Potassium	ppm	ASTM D5185m	>20	12	<1	2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	▲ 381431 ▲ 200470	▲ 187226 ▲ 04070	166637
Particles >6µm		ASTM D7647	>5000	▲ 299179	▲ 91973 ▲ 1707	▲ 59045 ▲ 1507
Particles >14µm		ASTM D7647	>640	▲ 29794 ▲ 1022	1707	▲ 1587 ▲ 265
Particles >21µm		ASTM D7647 ASTM D7647		<u>^</u> 1022	240	<u>^</u> 265
Particles >38μm Particles >71μm		ASTM D7647	>40 >10	2	2	2
Oil Cleanliness		ISO 4406 (c)	>10	± 26/25/22	± 25/24/18	△ 25/23/18
	TION					
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KFS0004640 Lab Number : 06179317

Unique Number : 11030643

Tested Diagnosed Test Package : IND 2 (Additional Tests: PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

CONSTELLIUM

4805 SECOND STREET MUSCLE SHOALS, AL US 35661

Contact: Randy Nichols randall.nichols@constellium.com T: (256)386-6956

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received

: 14 May 2024

: 15 May 2024

: 16 May 2024 - Angela Borella