




# OIL ANALYSIS REPORT

Sample Rating Trend



## ADDITIVES



Area

**HOTLINE/120 MILL**

Machine Id

**120 MILL MTR STAND 1 CENTER BRG 1415-033-0122**

Component

**Center Bearing**

Fluid

**ROYAL PURPLE SYNFILM GT 68 (30 GAL)**

### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

#### Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. Confirm oil type. The AN level is acceptable for this fluid.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KFS0004794</b>	KFS0002511	KFS0003401
Sample Date	Client Info		<b>10 May 2024</b>	20 Dec 2023	17 Apr 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

### CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>2	<b>NEG</b>	NEG	NEG

### WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>20	<b>0</b>	<1	1
Chromium	ppm	ASTM D5185m	>20	<b>0</b>	<1	0
Nickel	ppm	ASTM D5185m	>20	<b>1</b>	0	0
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>20	<b>&lt;1</b>	2	<1
Lead	ppm	ASTM D5185m	>20	<b>22</b>	21	▲ 72
Copper	ppm	ASTM D5185m	>20	<b>1</b>	1	5
Tin	ppm	ASTM D5185m	>20	<b>14</b>	12	▲ 43
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>0</b>	0	0
Barium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>0</b>	0	0
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	0	<1
Magnesium	ppm	ASTM D5185m	90	● <b>8</b>	● 7	90
Calcium	ppm	ASTM D5185m		<b>1</b>	<1	2
Phosphorus	ppm	ASTM D5185m		<b>49</b>	● 83	6
Zinc	ppm	ASTM D5185m		<b>0</b>	0	1
Sulfur	ppm	ASTM D5185m		● <b>6035</b>	● 5217	22494

### CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>15	<b>0</b>	<1	0
Sodium	ppm	ASTM D5185m		<b>&lt;1</b>	0	<1
Potassium	ppm	ASTM D5185m	>20	<b>2</b>	<1	0


### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ <b>59961</b>	▲ 62626	▲ 40064
Particles >6µm	ASTM D7647	>2500	<b>1742</b>	● 4521	● 3712
Particles >14µm	ASTM D7647	>160	<b>17</b>	21	77
Particles >21µm	ASTM D7647	>40	<b>4</b>	5	11
Particles >38µm	ASTM D7647	>10	<b>0</b>	1	1
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/14	▲ <b>23/18/11</b>	▲ 23/19/12	▲ 23/19/13


### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.31</b>	0.28	0.39


### ▲ Particle Trend




### ▲ Particle Trend



### Acid Number




### Viscosity @ 40°C







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 68	<b>69.5</b>	69.1	68.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KFS0004794      **Received** : 14 May 2024  
**Lab Number** : **06179331**      **Tested** : 16 May 2024  
**Unique Number** : 11030657      **Diagnosed** : 16 May 2024 - Angela Borella  
**Test Package** : IND 2 ( Additional Tests: PrtCount )

**CONSTELLIUM**  
 4805 SECOND STREET  
 MUSCLE SHOALS, AL  
 US 35661  
 Contact: Joel Even  
 joel.even@constellium.com  
 T: (256)740-7490  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)