




OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area

HOTLINE/120 MILL

Machine Id

120 MILL MTR STAND 2A NORTH BRG 1415-034-0211

Component

North Bearing

Fluid

ROYAL PURPLE SYNFLM GT 68 (30 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

The lead level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KFS0004811	KFS0003072	KFS0003399
Sample Date	Client Info	10 May 2024	20 Dec 2023	17 Apr 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >2	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >20	2	4	6
Chromium	ppm ASTM D5185m >20	0	<1	0
Nickel	ppm ASTM D5185m >20	1	0	0
Titanium	ppm ASTM D5185m	0	0	0
Silver	ppm ASTM D5185m	0	0	0
Aluminum	ppm ASTM D5185m >20	<1	2	<1
Lead	ppm ASTM D5185m >20	▲ 38	▲ 47	▲ 45
Copper	ppm ASTM D5185m >20	<1	<1	<1
Tin	ppm ASTM D5185m >20	2	1	2
Vanadium	ppm ASTM D5185m	0	0	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	0	0	0
Barium	ppm ASTM D5185m	<1	0	0
Molybdenum	ppm ASTM D5185m	0	0	0
Manganese	ppm ASTM D5185m	<1	0	<1
Magnesium	ppm ASTM D5185m 90	59	78	84
Calcium	ppm ASTM D5185m	2	2	2
Phosphorus	ppm ASTM D5185m	7	34	7
Zinc	ppm ASTM D5185m	10	0	16
Sulfur	ppm ASTM D5185m	21654	21418	22525

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >15	<1	1	<1
Sodium	ppm ASTM D5185m	1	<1	1
Potassium	ppm ASTM D5185m >20	2	<1	0


FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	▲ 45080	5901	▲ 51723
Particles >6µm	ASTM D7647 >2500	1463	968	▲ 9598
Particles >14µm	ASTM D7647 >160	85	92	● 226
Particles >21µm	ASTM D7647 >40	23	34	36
Particles >38µm	ASTM D7647 >10	1	4	2
Particles >71µm	ASTM D7647 >3	0	1	0
Oil Cleanliness	ISO 4406 (c) >20/18/14	▲ 23/18/14	20/17/14	▲ 23/20/15


FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045	0.40	0.38	0.39


▲ Particle Trend




▲ Particle Trend




▲ Non-ferrous Metals



Acid Number



Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 68	70.0	69.1	69.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color




Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : KFS0004811

Lab Number : 06179338

Unique Number : 11030664

Test Package : IND 2 (Additional Tests: PrtCount)

Received : 14 May 2024

Tested : 16 May 2024

Diagnosed : 16 May 2024 - Angela Borella

CONSTELLIUM

4805 SECOND STREET

MUSCLE SHOALS, AL

US 35661

Contact: Joel Even

joel.even@constellium.com

T: (256)740-7490

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)