




OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
DICK LAVY
 Machine Id
DICK LAVY 4836
 Component
Transmission (Manual)
 Fluid
{not provided} (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition. Please specify the brand, type, and viscosity of the oil on your next sample. Please note that this is a corrected copy for laboratory data updates to retest ICP data.

Wear

The iron level is abnormal. The copper level is abnormal.

Contamination

There is a high amount of particulates present in the fluid.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0900736	WC0853954	WC0815544
Sample Date	Client Info		14 Mar 2024	08 Sep 2023	22 Apr 2023
Machine Age	mls	Client Info	362312	292683	243556
Oil Age	mls	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >200	▲ 238	▲ 199	▲ 215
Chromium	ppm	ASTM D5185m >5	4	3	3
Nickel	ppm	ASTM D5185m >5	<1	<1	<1
Titanium	ppm	ASTM D5185m	<1	<1	<1
Silver	ppm	ASTM D5185m >7	<1	0	0
Aluminum	ppm	ASTM D5185m >25	10	12	12
Lead	ppm	ASTM D5185m >45	<1	7	<1
Copper	ppm	ASTM D5185m >225	▲ 352	▲ 269	▲ 281
Tin	ppm	ASTM D5185m >10	<1	<1	<1
Vanadium	ppm	ASTM D5185m	<1	<1	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	265	216	258
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	3	2	2
Manganese	ppm	ASTM D5185m	28	24	28
Magnesium	ppm	ASTM D5185m	2	2	2
Calcium	ppm	ASTM D5185m	210	183	220
Phosphorus	ppm	ASTM D5185m	1361	1089	1251
Zinc	ppm	ASTM D5185m	36	28	18
Sulfur	ppm	ASTM D5185m	2337	885	1365

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >125	18	15	14
Sodium	ppm	ASTM D5185m	1	3	0
Potassium	ppm	ASTM D5185m >20	3	4	2
Water	%	ASTM D6304 >0.1	0.049	0.058	0.048
ppm Water	ppm	ASTM D6304 >1000	497	587.7	484.0






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 55290	▲ 41594	▲ 50947
Particles >6µm	ASTM D7647	>2500	▲ 10695	● 4155	● 3877
Particles >14µm	ASTM D7647	>320	▲ 565	71	70
Particles >21µm	ASTM D7647	>80	▲ 137	20	14
Particles >38µm	ASTM D7647	>20	4	2	2
Particles >71µm	ASTM D7647	>4	0	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 23/21/16	▲ 23/19/13	▲ 23/19/13

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	3.19	3.07	3.25

OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	58.5	57.7	58.1
Visc @ 100°C	cSt	ASTM D445	10.1	10.0	9.9
Viscosity Index (VI)	Scale	ASTM D2270	160	161	157

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0900736 **Received** : 14 May 2024
Lab Number : 06179365 **Tested** : 21 May 2024
Unique Number : 11030691 **Diagnosed** : 21 May 2024 - Jonathan Hester
Test Package : MOB 2 (Additional Tests: KF, KV100, PrtCount, VI)

BASF - GIANNA CREDAROLI
 500 WHITE PLAINS RD
 TARRYTOWN, NY
 US 10591
 Contact: GIANNA CREDAROLI
 gianna.credaroli@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)