




# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**COWAN**  
 Machine Id  
**COWAN 224525**  
 Component  
**Rear Differential**  
 Fluid  
 {not provided} (--- GAL)

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0900730</b>	WC0828675	---
Sample Date	Client Info		<b>02 Jan 2024</b>	13 Jun 2023	---
Machine Age	mls	Client Info	<b>61577</b>	531	---
Oil Age	mls	Client Info	<b>0</b>	0	---
Oil Changed	Client Info		<b>N/A</b>	N/A	---
Sample Status			<b>ABNORMAL</b>	ABNORMAL	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >500	<b>152</b>	16	---
Chromium	ppm	ASTM D5185m >10	<b>2</b>	<1	---
Nickel	ppm	ASTM D5185m >10	<b>5</b>	<1	---
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	0	---
Silver	ppm	ASTM D5185m	<b>0</b>	0	---
Aluminum	ppm	ASTM D5185m >25	<b>2</b>	0	---
Lead	ppm	ASTM D5185m >25	<b>0</b>	0	---
Copper	ppm	ASTM D5185m >100	<b>&lt;1</b>	0	---
Tin	ppm	ASTM D5185m >10	<b>2</b>	<1	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	---
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>127</b>	124	---
Barium	ppm	ASTM D5185m	<b>2</b>	0	---
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	---
Manganese	ppm	ASTM D5185m	<b>8</b>	1	---
Magnesium	ppm	ASTM D5185m	<b>153</b>	172	---
Calcium	ppm	ASTM D5185m	<b>7</b>	2	---
Phosphorus	ppm	ASTM D5185m	<b>1724</b>	1777	---
Zinc	ppm	ASTM D5185m	<b>6</b>	0	---
Sulfur	ppm	ASTM D5185m	<b>30186</b>	32615	---

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >75	<b>27</b>	8	---
Sodium	ppm	ASTM D5185m	<b>4</b>	2	---
Potassium	ppm	ASTM D5185m >20	<b>2</b>	2	---
Water	%	ASTM D6304 >.2	<b>0.032</b>	0.034	---
ppm Water	ppm	ASTM D6304 >2000	<b>326</b>	348.5	---






## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	<b>▲ 142912</b>	▲ 99898	---
Particles >6µm	ASTM D7647	>5000	<b>● 7756</b>	▲ 13506	---
Particles >14µm	ASTM D7647	>640	<b>55</b>	197	---
Particles >21µm	ASTM D7647	>160	<b>8</b>	29	---
Particles >38µm	ASTM D7647	>40	<b>0</b>	0	---
Particles >71µm	ASTM D7647	>10	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>▲ 24/20/13</b>	▲ 24/21/15	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.79</b>	0.86	---


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>.2	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	59.6	58.4	---
Visc @ 100°C	cSt	ASTM D445	10.5	10.4	---
Viscosity Index (VI)	Scale	ASTM D2270	167	168	---

### SAMPLE IMAGES



### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0900730 **Received** : 14 May 2024  
**Lab Number** : 06179369 **Tested** : 16 May 2024  
**Unique Number** : 11030695 **Diagnosed** : 16 May 2024 - Angela Borella  
**Test Package** : MOB 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**BASF - GIANNA CREDAROLI**  
 500 WHITE PLAINS RD  
 TARRYTOWN, NY  
 US 10591  
 Contact: GIANNA CREDAROLI  
 gianna.credaroli@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)