




# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Area  
**METRO**  
 Machine Id  
**METRO 20001**  
 Component  
**Front Differential**  
 Fluid  
 {not provided} (--- GAL)

### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a moderate amount of silt (particulates < 6 microns in size) present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0934469</b>	WC0828737	WC0682394
Sample Date	Client Info		<b>28 Feb 2024</b>	26 Jun 2023	11 Mar 2022
Machine Age	mls	Client Info	<b>441410</b>	355229	265136
Oil Age	mls	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ATTENTION</b>	ATTENTION	NORMAL

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >500	<b>439</b>	368	353
Chromium	ppm	ASTM D5185m >10	<b>3</b>	3	3
Nickel	ppm	ASTM D5185m >10	<b>3</b>	2	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>4</b>	3	3
Lead	ppm	ASTM D5185m >25	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185m >100	<b>2</b>	2	2
Tin	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Antimony	ppm	ASTM D5185m >5	<b>---</b>	---	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>55</b>	55	57
Barium	ppm	ASTM D5185m	<b>2</b>	2	0
Molybdenum	ppm	ASTM D5185m	<b>&lt;1</b>	2	<1
Manganese	ppm	ASTM D5185m	<b>9</b>	8	8
Magnesium	ppm	ASTM D5185m	<b>158</b>	151	169
Calcium	ppm	ASTM D5185m	<b>6</b>	6	4
Phosphorus	ppm	ASTM D5185m	<b>1692</b>	1618	1801
Zinc	ppm	ASTM D5185m	<b>9</b>	11	5
Sulfur	ppm	ASTM D5185m	<b>27728</b>	24233	19689

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >75	<b>56</b>	52	47
Sodium	ppm	ASTM D5185m	<b>9</b>	4	6
Potassium	ppm	ASTM D5185m >20	<b>5</b>	5	4
Water	%	ASTM D6304 >.2	<b>0.039</b>	0.033	0.041
ppm Water	ppm	ASTM D6304 >2000	<b>393</b>	335.2	419.9

### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	<b>23370</b>	21046	---
Particles >6µm	ASTM D7647	>5000	<b>1414</b>	643	---
Particles >14µm	ASTM D7647	>640	<b>18</b>	27	---
Particles >21µm	ASTM D7647	>160	<b>4</b>	9	---
Particles >38µm	ASTM D7647	>40	<b>0</b>	0	---
Particles >71µm	ASTM D7647	>10	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>22/18/11</b>	22/17/12	---


### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>1.21</b>	1.07	0.82




# OIL ANALYSIS REPORT


## Particle Trend




## Water (KF)




## Viscosity @ 100°C



## Water (KF)




## Viscosity @ 100°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	47.17	47.4	48.2
Visc @ 100°C	cSt	ASTM D445	8.7	8.8	9.1
Viscosity Index (VI)	Scale	ASTM D2270	165	167	173

## SAMPLE IMAGES




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### Particle Count



### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0934469  
**Lab Number** : 06179391  
**Unique Number** : 11030717  
**Test Package** : MOB 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**Received** : 14 May 2024  
**Tested** : 21 May 2024  
**Diagnosed** : 21 May 2024 - Jonathan Hester

**BASF - GIANNA CREDAROLI**  
 500 WHITE PLAINS RD  
 TARRYTOWN, NY  
 US 10591  
 Contact: GIANNA CREDAROLI  
 gianna.credaroli@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)