


# PROBLEM SUMMARY

## Sample Rating Trend




ISO




Area  
**TM 8**  
 Machine Id  
**TM 8 SOUTH VACUUM PUMP**  
 Component  
**Pump**  
 Fluid  
**ROYAL PURPLE SYNFILM GT220 (35 GAL)**

## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



### ▲ Non-ferrous Metals



## RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ATTENTION	ABNORMAL
Copper	ppm	ASTM D5185m >30	▲ 45	34	16
Particles >4µm		ASTM D7647 >5000	▲ 19834	39363	---
Particles >6µm		ASTM D7647 >1300	▲ 2953	9096	---
Oil Cleanliness		ISO 4406 (c) >19/17/14	▲ 21/19/14	22/20/17	---

Customer Id: KIMMOBTM8  
 Sample No.: RP0037982  
 Lab Number: 06179418  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.

HISTORICAL DIAGNOSIS

ISO



**25 Oct 2022 Diag: Angela Borella**

Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



VIS DEBRIS



**16 May 2021 Diag: Don Baldrige**

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



ISO



**25 May 2020 Diag: Don Baldrige**

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**TM 8**  
 Machine Id  
**TM 8 SOUTH VACUUM PUMP**  
 Component  
**Pump**  
 Fluid  
**ROYAL PURPLE SYNFILM GT220 (35 GAL)**

## DIAGNOSIS

### ▲ Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

### ▲ Wear

The copper level is abnormal. All other component wear rates are normal.

### ▲ Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>RP0037982</b>	RP0023372	RP05256013
Sample Date	Client Info		<b>30 Apr 2024</b>	25 Oct 2022	16 May 2021
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	ATTENTION	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >90	<b>15</b>	13	5
Chromium	ppm	ASTM D5185m >5	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >5	<b>1</b>	0	<1
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >3	<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185m >7	<b>&lt;1</b>	<1	0
Lead	ppm	ASTM D5185m >12	<b>3</b>	2	1
Copper	ppm	ASTM D5185m >30	<b>▲ 45</b>	34	16
Tin	ppm	ASTM D5185m >9	<b>&lt;1</b>	<1	<1
Antimony	ppm	ASTM D5185m	<b>---</b>	---	1
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>3</b>	0	11
Barium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m 90	<b>2</b>	0	0
Calcium	ppm	ASTM D5185m	<b>22</b>	22	20
Phosphorus	ppm	ASTM D5185m	<b>98</b>	82	81
Zinc	ppm	ASTM D5185m	<b>12</b>	19	15

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >60	<b>5</b>	3	2
Sodium	ppm	ASTM D5185m	<b>2</b>	0	1
Potassium	ppm	ASTM D5185m >20	<b>1</b>	0	0
Water	%	ASTM D6304 >.1	<b>0.007</b>	0.013	0.004
ppm Water	ppm	ASTM D6304 >1000	<b>79</b>	131.9	41.6

## FLUID CLEANLINESS


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>▲ 19834</b>	● 39363	---
Particles >6µm	ASTM D7647	>1300	<b>▲ 2953</b>	● 9096	---
Particles >14µm	ASTM D7647	>160	<b>156</b>	● 919	---
Particles >21µm	ASTM D7647	>40	<b>23</b>	● 257	---
Particles >38µm	ASTM D7647	>10	<b>1</b>	10	---
Particles >71µm	ASTM D7647	>3	<b>1</b>	0	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>▲ 21/19/14</b>	● 22/20/17	---

## FLUID DEGRADATION


	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.25	<b>0.31</b>	0.31	0.223

# OIL ANALYSIS REPORT


### ▲ Particle Trend




### Water (KF)




### ▲ Non-ferrous Metals



### Acid Number



### Water (KF)



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220	210	210

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color




Bottom




### GRAPHS


#### Ferrous Alloys




#### ▲ Non-ferrous Metals




#### Viscosity @ 40°C



#### ▲ Particle Count



#### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513

**Sample No.** : RP0037982

**Lab Number** : 06179418

**Unique Number** : 11030744

**Test Package** : IND 2 ( Additional Tests: PrtCount )

**Received** : 14 May 2024

**Tested** : 21 May 2024

**Diagnosed** : 21 May 2024 - Jonathan Hester

**Kimberly-Clark - Mobile - TM 8**

200 BAYBRIDGE RD

MOBILE, AL

US 36610

Contact: LARRY WEAVER

Larry.D.Weaver@kcc.com

T: (251)330-2356

F: (251)452-6335

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)