




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
CHLR-2A

Component
Turbine

Fluid
ROYAL PURPLE SYNFILM GT 32 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	RP0043282	RP0041522	RP0039507
Sample Date	Client Info	13 May 2024	12 May 2024	17 Apr 2024
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	NORMAL	SEVERE

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >15	0	0	0
Chromium	ppm	ASTM D5185m >4	0	<1	0
Nickel	ppm	ASTM D5185m >2	<1	0	0
Titanium	ppm	ASTM D5185m	0	<1	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >10	<1	2	0
Lead	ppm	ASTM D5185m	0	<1	2
Copper	ppm	ASTM D5185m >5	0	<1	2
Tin	ppm	ASTM D5185m >5	<1	<1	0
Vanadium	ppm	ASTM D5185m	0	0	<1
Cadmium	ppm	ASTM D5185m	0	<1	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	<1	2	0
Molybdenum	ppm	ASTM D5185m	0	<1	0
Manganese	ppm	ASTM D5185m	<1	0	<1
Magnesium	ppm	ASTM D5185m	104	97	<1
Calcium	ppm	ASTM D5185m	3	5	0
Phosphorus	ppm	ASTM D5185m	8	6	0
Zinc	ppm	ASTM D5185m	0	2	1

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	0	<1	2
Sodium	ppm	ASTM D5185m	2	0	0
Potassium	ppm	ASTM D5185m >20	2	1	1
Water	%	ASTM D6304 >0.03	0.022	0.021	▲ 0.330
ppm Water	ppm	ASTM D6304 >300	229	219	▲ 3300

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >2500	▲ 25954	---	---
Particles >6µm	ASTM D7647 >640	▲ 7463	---	---
Particles >14µm	ASTM D7647 >80	▲ 747	---	---
Particles >21µm	ASTM D7647 >20	238	---	---
Particles >38µm	ASTM D7647 >4	▲ 21	---	---
Particles >71µm	ASTM D7647 >3	4	---	---
Oil Cleanliness	ISO 4406 (c) >18/16/13	▲ 22/20/17	---	---

FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.46	0.43	0.13

OIL ANALYSIS REPORT


▲ Particle Trend




Water (KF)




Acid Number



Water (KF)



Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.03	NEG	▲ 0.2%
Free Water	scalar	*Visual		NEG	▲ >10%

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	32	33.5	32.7

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color




Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : RP0043282

Lab Number : 06179424

Unique Number : 11030750

Test Package : IND 2 (Additional Tests: PrtCount)

Received : 14 May 2024

Tested : 16 May 2024

Diagnosed : 16 May 2024 - Angela Borella

ENGIE-MATEP

474 BROOKLINE AVE

BOSTON, MA

US 02215

Contact: ROBERT ST SAUVEUR

robert.stsauveur@engie.com

T: (401)651-9381

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)