


## **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER 6950570

Component Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

### DIAGNOSIS

#### Recommendation

We recommend you service the filters on this component. We were unable to perform a particle count due to a high concentration of particles present in this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

#### Wear

All component wear rates are normal.

#### Contamination

High concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil.


## Fluid Condition


The AN level is acceptable for this fluid.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC129932	KC121111	KC124470
Sample Date		Client Info		08 Apr 2024	27 Dec 2023	15 Aug 2023
Machine Age	hrs	Client Info		9370	9081	8791
Oil Age	hrs	Client Info		579	0	0
Oil Changed		Client Info		Not Changd	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	000	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m		0	0	<1
Nickel	ppm	ASTM D5185m		۰ <1	0	<1
	ppm		>3			
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m		<1	0	2
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m		7	13	6
Tin	ppm	ASTM D5185m	>10	<1	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	3	0	4
Molybdenum	ppm	ASTM D5185m		0	0	<1
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	90	47	55	52
Calcium	ppm	ASTM D5185m	2	3	0	6
Phosphorus	ppm	ASTM D5185m		13	4	6
Zinc	ppm	ASTM D5185m		28	79	19
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	2	<1
Sodium	ppm	ASTM D5185m		14	14	13
Potassium	ppm	ASTM D5185m	>20	5	3	7
Water	%	ASTM D6304	>0.05	<b>A</b> 0.289	0.016	<b>0.246</b>
ppm Water	ppm	ASTM D6304	>500	<b>A</b> 2890	163	<b>4</b> 2460
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			42944	2962
Particles >6µm		ASTM D7647	>1300		<b>1</b> 2168	270
Particles >14µm		ASTM D7647	>80		<b>1</b> 153	12
Particles >21µm		ASTM D7647	>20		▲ 324	3
Particles >38µm		ASTM D7647	>4		<u>▲</u> 14	0
Particles >71µm		ASTM D7647	>3		1	0
Oil Cleanliness		ISO 4406 (c)	>/17/13		▲ 23/21/17	19/15/11
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.42	0.463	0.32
( -)	0 - 0					




# **OIL ANALYSIS REPORT**









VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	🔺 HEAVY	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	🛑 HAZY	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	<b>6.2%</b>	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.9	45.1	44.4
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color				a. 00		a.



Bottom





\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate 12367

Contact/Location: Service Manager - HERGRAKC

T:

F: