

OIL ANALYSIS REPORT



Machine Id

5836341 (S/N 1010)

Component Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

Confirm oil type. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017230		
Sample Date		Client Info		09 May 2024		
Machine Age	hrs	Client Info		754		
Oil Age	hrs	Client Info		700		
Oil Changed		Client Info		Changed		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	11		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	<1		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	3		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	90	7		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m		1		
Magnesium	ppm	ASTM D5185m	100	33		
Calcium	ppm	ASTM D5185m	0	6		
Phosphorus	ppm	ASTM D5185m	0	5		
Zinc	ppm	ASTM D5185m	0	52		
Sulfur	ppm	ASTM D5185m	23500	22921		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4		
Sodium	ppm	ASTM D5185m		104		
Potassium	ppm	ASTM D5185m	>20	17		
Water	%	ASTM D6304	>0.05	0.023		
ppm Water	ppm	ASTM D6304	>500	232		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		286315		
Particles >6µm		ASTM D7647	>1300	<mark>/</mark> 98392		
Particles >14µm		ASTM D7647	>80	A 3189		
Particles >21µm		ASTM D7647	>20	<u> </u>		
Particles >38µm		ASTM D7647	>4	🔺 11		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	^ 25/24/19		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



Built for a lifetime

🔺 Particle Trend

Water (KF)

Acid Number

Water (KF)

Abnormal

Viscosity @ 40°C

_14µm

300

250

200

150

100

50

0

12000

1000

800 (maa)

600 Water 400

200

1.20

(B/H0) Ê0.7

Ê n 41

Poid 0.2

0.00

1000

600 Water (

4000

200

60

55

<u>ှ</u> 5(

-₹3 45 B


40


35

Se

Abnormal

Se





Report Id: CITWATWI [WUSCAR] 06179462 (Generated: 05/17/2024 11:58:07) Rev: 1

Contact/Location: Service Manager - CITWATWI