


PROBLEM SUMMARY

Sample Rating Trend





WATER



Machine Id
SEFTON (S/N 97031197)
Component
Natural Gas Engine
Fluid
{not provided} (--- QTS)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	ABNORMAL
Iron	ppm	ASTM D5185m	>50	▲ 250	137	▲ 157
Water	%	ASTM D6304	>0.1	▲ 3.81	▲ 0.392	▲ 0.615
ppm Water	ppm	ASTM D6304	>1000	▲ 38100	▲ 3920	▲ 6150
Silt	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Emulsified Water	scalar	*Visual	>0.1	▲ 0.2%	NEG	NEG

Customer Id: WARWARRI
Sample No.: RP0039511
Lab Number: 06179513
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Sean Felton +1 919-379-4092
sfelton@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the oil and perform a filter service on this component if not already done.
Change Filter	---	---	?	We recommend that you drain the oil and perform a filter service on this component if not already done.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

WATER



11 Jan 2021 Diag: Jonathan Hester

We advise that you check for the source of water entry. No corrective action is recommended at this time. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. Please note that there was too much water present in the oil to perform an accurate viscosity test. All component wear rates are normal. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid.

view report



WATER



20 Nov 2018 Diag: Jonathan Hester

We advise that you check for the source of water entry. Resample at the next service interval to monitor. Cylinder, crank, or cam shaft wear is indicated. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



GLYCOL



20 Dec 2017 Diag: Doug Bogart


We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Cylinder, crank, or cam shaft wear is indicated. Test for glycol is positive. There is a light concentration of water present in the oil. Trace concentration of anti-freeze present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
SEFTON (S/N 97031197)
 Component
Natural Gas Engine
 Fluid
 {not provided} (--- QTS)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition.

Wear

The iron level is abnormal.

Contamination

There is a high concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. There is a moderate amount of visible silt present in the sample.

Fluid Condition

The oil is no longer serviceable due to the presence of contaminants.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			RP0039511	RP0013481	RP203749
Sample Date	Client Info			19 Apr 2024	11 Jan 2021	20 Nov 2018
Machine Age	hrs	Client Info		198	197	196
Oil Age	hrs	Client Info		0	0	0
Oil Changed	Client Info			N/A	N/A	N/A
Sample Status				SEVERE	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	▲ 250	137	▲ 157
Chromium	ppm	ASTM D5185m	>4	<1	<1	<1
Nickel	ppm	ASTM D5185m	>2	<1	<1	<1
Titanium	ppm	ASTM D5185m		<1	<1	<1
Silver	ppm	ASTM D5185m	>3	0	<1	0
Aluminum	ppm	ASTM D5185m	>9	5	6	2
Lead	ppm	ASTM D5185m	>30	4	3	4
Copper	ppm	ASTM D5185m	>35	8	22	9
Tin	ppm	ASTM D5185m	>4	2	3	0
Antimony	ppm	ASTM D5185m		---	0	2
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		1	<1	<1






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		11	16	20
Barium	ppm	ASTM D5185m		2	0	0
Molybdenum	ppm	ASTM D5185m		116	8	18
Manganese	ppm	ASTM D5185m		1	<1	<1
Magnesium	ppm	ASTM D5185m		536	15	5
Calcium	ppm	ASTM D5185m		1803	2067	775
Phosphorus	ppm	ASTM D5185m		296	375	391
Zinc	ppm	ASTM D5185m		354	384	302

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	10	6	6
Sodium	ppm	ASTM D5185m		6	9	11
Potassium	ppm	ASTM D5185m	>20	3	<1	0
Water	%	ASTM D6304	>0.1	▲ 3.81	▲ 0.392	▲ 0.615
ppm Water	ppm	ASTM D6304	>1000	▲ 38100	▲ 3920	▲ 6150
Glycol	%	*ASTM D2982		---	---	---

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0.3	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	8.0	7.1	9.1
Sulfation	Abs/.1mm	*ASTM D7415	>30	30.0	22.8	25.7

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	51.8	20.3	37
Acid Number (AN)	mg KOH/g	ASTM D8045		---	1.291	1.672
Base Number (BN)	mg KOH/g	ASTM D2896		8.60	---	---





OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	▲ MODER	NONE	NONE
Debris	scalar	*Visual	▲ MODER	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	● LAYRD	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	▲ 0.2%	NEG	NEG
Free Water	scalar	*Visual	● 25.0	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	11.6	● 5.1	8.16

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0039511 **Received** : 14 May 2024
Lab Number : 06179513 **Tested** : 17 May 2024
Unique Number : 11030839 **Diagnosed** : 17 May 2024 - Sean Felton
Test Package : IND 2 (Additional Tests: FT-IR, Glycol, KV100, TBN)

WARWICK SEWER AUTHORITY
 125 ARTHUR DEVINE BLVD
 WARWICK, RI
 US 02888
 Contact: JOHN BROSNAHAN
 john.s.brosnahan@warwickri.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: