




# OIL ANALYSIS REPORT

## Sample Rating Trend



**NORMAL**



Machine Id  
**BELLOWS ST**  
 Component  
**Natural Gas Engine**  
 Fluid  
 {not provided} (--- GAL)

### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>RP0039517</b>	RP0016532	RP203752
Sample Date	Client Info			<b>19 Apr 2024</b>	20 Jan 2021	20 Nov 2018
Machine Age	hrs	Client Info		<b>69</b>	60	53
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>8</b>	8	6
Chromium	ppm	ASTM D5185m	>4	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m	>2	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Silver	ppm	ASTM D5185m	>3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>9	<b>3</b>	6	1
Lead	ppm	ASTM D5185m	>30	<b>&lt;1</b>	1	<1
Copper	ppm	ASTM D5185m	>35	<b>3</b>	8	2
Tin	ppm	ASTM D5185m	>4	<b>&lt;1</b>	<1	0
Antimony	ppm	ASTM D5185m		<b>---</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>3</b>	18	51
Barium	ppm	ASTM D5185m		<b>&lt;1</b>	0	<1
Molybdenum	ppm	ASTM D5185m		<b>124</b>	31	5
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>850</b>	11	7
Calcium	ppm	ASTM D5185m		<b>2912</b>	2865	1607
Phosphorus	ppm	ASTM D5185m		<b>309</b>	536	594
Zinc	ppm	ASTM D5185m		<b>331</b>	542	385


CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	<b>17</b>	11	19
Sodium	ppm	ASTM D5185m		<b>&lt;1</b>	5	2
Potassium	ppm	ASTM D5185m	>20	<b>4</b>	2	0
Water	%	ASTM D6304	>0.1	<b>NEG</b>	NEG	NEG

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		<b>0.1</b>	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	<b>6.6</b>	5.4	5.9
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>36.0</b>	25.3	33


FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>50.3</b>	18.6	40.6
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>---</b>	0.729	0.954
Base Number (BN)	mg KOH/g	ASTM D2896		<b>12.62</b>	---	---

# OIL ANALYSIS REPORT


FT-IR (Direct Trend)




Base Number




Viscosity @ 100°C



Viscosity @ 40°C



Acid Number




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	12.3	11.2	10.24

**GRAPHS**


Ferrous Alloys




Non-ferrous Metals



Viscosity @ 100°C



Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : RP0039517  
**Lab Number** : 06179518  
**Unique Number** : 11030844  
**Test Package** : IND 2 ( Additional Tests: FT-IR, KV100, TBN )  
**Received** : 14 May 2024  
**Tested** : 17 May 2024  
**Diagnosed** : 17 May 2024 - Sean Felton

**WARWICK SEWER AUTHORITY**  
 125 ARTHUR DEVINE BLVD  
 WARWICK, RI  
 US 02888  
 Contact: JOHN BROSNAHAN  
 john.s.brosnahan@warwickri.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)