




OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id

TIDEWATER (S/N CBP00156)

Component

Natural Gas Engine

Fluid

{not provided} (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

The copper level is abnormal. In the absence of other significant wear metals, suspect copper due to sources other than wear (i.e. cooling core).

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		RP0026040	RP0025714	RP0013473
Sample Date	Client Info		28 Mar 2024	31 Mar 2022	12 Jan 2021
Machine Age	hrs	Client Info	270	257	231
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	4	3	6
Chromium	ppm	ASTM D5185m	>4	<1	0	<1
Nickel	ppm	ASTM D5185m	>2	<1	0	<1
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m	>3	0	0	<1
Aluminum	ppm	ASTM D5185m	>9	3	1	5
Lead	ppm	ASTM D5185m	>30	<1	1	1
Copper	ppm	ASTM D5185m	>35	▲ 74	▲ 103	▲ 102
Tin	ppm	ASTM D5185m	>4	<1	0	<1
Antimony	ppm	ASTM D5185m		---	---	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	<1

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		4	62	36
Barium	ppm	ASTM D5185m		<1	0	0
Molybdenum	ppm	ASTM D5185m		126	5	6
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		942	8	18
Calcium	ppm	ASTM D5185m		2789	1636	2237
Phosphorus	ppm	ASTM D5185m		340	651	502
Zinc	ppm	ASTM D5185m		349	478	395

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>+100	11	5	7
Sodium	ppm	ASTM D5185m		0	0	2
Potassium	ppm	ASTM D5185m	>20	2	1	1
Water	%	ASTM D6304	>0.1	NEG	NEG	NEG





INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		0.1	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	6.4	6.5	5.5
Sulfation	Abs/.1mm	*ASTM D7415	>30	38.7	35.4	30.1

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	57.1	44.0	29.9
Acid Number (AN)	mg KOH/g	ASTM D8045		---	---	0.922
Base Number (BN)	mg KOH/g	ASTM D2896		12.96	6.01	---





OIL ANALYSIS REPORT



PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	12.6	10.3	10.7

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0026040 **Received** : 14 May 2024
Lab Number : 06179525 **Tested** : 17 May 2024
Unique Number : 11030851 **Diagnosed** : 17 May 2024 - Sean Felton
Test Package : IND 2 (Additional Tests: FT-IR, KV100, TBN)

WARWICK SEWER AUTHORITY
 125 ARTHUR DEVINE BLVD
 WARWICK, RI
 US 02888
 Contact: JOHN BROSNAHAN
 john.s.brosnahan@warwickri.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)