




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**BROOKWOOD (S/N GXB04175-OLY00000)**

Component  
**Natural Gas Engine**

Fluid  
**{not provided} (--- QTS)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

### Wear

Metal levels are typical for a new component breaking in.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>RP0026038</b>	RP0016528	RP203916
Sample Date	Client Info			<b>10 Apr 2024</b>	19 Jan 2021	23 Oct 2018
Machine Age	hrs	Client Info		<b>39</b>	11	7
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>16</b>	15	26
Chromium	ppm	ASTM D5185m	>4	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m	>2	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Silver	ppm	ASTM D5185m	>3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>9	<b>4</b>	6	3
Lead	ppm	ASTM D5185m	>30	<b>&lt;1</b>	1	6
Copper	ppm	ASTM D5185m	>35	<b>9</b>	9	34
Tin	ppm	ASTM D5185m	>4	<b>&lt;1</b>	<1	0
Antimony	ppm	ASTM D5185m		<b>---</b>	0	1
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	0
Cadmium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>6</b>	91	196
Barium	ppm	ASTM D5185m		<b>&lt;1</b>	0	<1
Molybdenum	ppm	ASTM D5185m		<b>131</b>	21	67
Manganese	ppm	ASTM D5185m		<b>1</b>	2	4
Magnesium	ppm	ASTM D5185m		<b>887</b>	71	14
Calcium	ppm	ASTM D5185m		<b>2847</b>	2862	2116
Phosphorus	ppm	ASTM D5185m		<b>303</b>	503	678
Zinc	ppm	ASTM D5185m		<b>343</b>	551	691


CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	<b>16</b>	37	70
Sodium	ppm	ASTM D5185m		<b>&lt;1</b>	10	5
Potassium	ppm	ASTM D5185m	>20	<b>3</b>	3	9
Water	%	ASTM D6304	>0.1	<b>NEG</b>	NEG	NEG

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		<b>0.1</b>	0.1	0
Nitration	Abs/cm	*ASTM D7624	>20	<b>6.7</b>	4.8	4.4
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>36.5</b>	21.7	15.3


FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>52.4</b>	13.7	9.2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>---</b>	0.562	1.066
Base Number (BN)	mg KOH/g	ASTM D2896		<b>13.33</b>	---	---

# OIL ANALYSIS REPORT


FT-IR (Direct Trend)




Base Number




Viscosity @ 100°C



Viscosity @ 40°C



Acid Number




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	12.5	10.8	9.48

## GRAPHS


Ferrous Alloys




Non-ferrous Metals



Viscosity @ 100°C



Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : RP0026038 **Received** : 14 May 2024  
**Lab Number** : 06179527 **Tested** : 17 May 2024  
**Unique Number** : 11030853 **Diagnosed** : 17 May 2024 - Sean Felton  
**Test Package** : IND 2 ( Additional Tests: FT-IR, KV100, TBN )

**WARWICK SEWER AUTHORITY**  
 125 ARTHUR DEVINE BLVD  
 WARWICK, RI  
 US 02888  
 Contact: JOHN BROSNAHAN  
 john.s.brosnahan@warwickri.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: