




OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
15191-1-04-98 BAYONNE
 Component
Natural Gas Engine
 Fluid
{not provided} (--- GAL)

DIAGNOSIS

- Recommendation**
Resample at the next service interval to monitor.
- Wear**
All component wear rates are normal.
- Contamination**
There is no indication of any contamination in the oil.
- Fluid Condition**
The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		RP151974	RP203729	RP181088
Sample Date	Client Info		22 Apr 2024	01 Oct 2018	07 Dec 2017
Machine Age	hrs	Client Info	375	351	346
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	9	38	17
Chromium	ppm	ASTM D5185m >4	<1	<1	<1
Nickel	ppm	ASTM D5185m >2	<1	<1	<1
Titanium	ppm	ASTM D5185m	<1	<1	<1
Silver	ppm	ASTM D5185m >3	1	3	1
Aluminum	ppm	ASTM D5185m >9	3	2	1
Lead	ppm	ASTM D5185m >30	2	4	2
Copper	ppm	ASTM D5185m >35	7	2	1
Tin	ppm	ASTM D5185m >4	1	0	0
Antimony	ppm	ASTM D5185m	---	2	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	37	38
Barium	ppm	ASTM D5185m	2	2	<1
Molybdenum	ppm	ASTM D5185m	106	21	16
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	794	14	11
Calcium	ppm	ASTM D5185m	2909	1910	1718
Phosphorus	ppm	ASTM D5185m	326	651	616
Zinc	ppm	ASTM D5185m	352	503	443

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >+100	11	8	7
Sodium	ppm	ASTM D5185m	<1	4	3
Potassium	ppm	ASTM D5185m >20	2	0	6
Water	%	ASTM D6304 >0.1	NEG	NEG	NEG

INFRA-RED


	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0.1	0.1	0
Nitration	Abs/cm	*ASTM D7624 >20	6.6	6.4	6.
Sulfation	Abs/.1mm	*ASTM D7415 >30	36.7	34	33.

FLUID DEGRADATION


	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	51.8	41.1	36.
Acid Number (AN)	mg KOH/g	ASTM D8045	---	1.123	0.779
Base Number (BN)	mg KOH/g	ASTM D2896	12.59	---	---

OIL ANALYSIS REPORT


FT-IR (Direct Trend)




Base Number




Viscosity @ 100°C



Viscosity @ 40°C



Acid Number




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	12.3	10.71	10.59

GRAPHS


Ferrous Alloys




Non-ferrous Metals



Viscosity @ 100°C



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP151974 **Received** : 14 May 2024
Lab Number : 06179534 **Tested** : 17 May 2024
Unique Number : 11030860 **Diagnosed** : 17 May 2024 - Sean Felton
Test Package : IND 2 (Additional Tests: FT-IR, KV100, TBN)

WARWICK SEWER AUTHORITY
 125 ARTHUR DEVINE BLVD
 WARWICK, RI
 US 02888
 Contact: JOHN BROSNAHAN
 john.s.brosnahan@warwickri.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)