


OIL ANALYSIS REPORT

Sample Rating Trend





Machine Id

VAC 1181696-6 P1 W-BTTM (S/N 200001932) Pump

USPI VAC 100 (--- GAL)

	VС	

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

	-662017 Oct2017 Aug2016 Mar2013 Fe62020 Nov2020 Nov2022 Nov2023 May202						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		USPM36157	USPM36820	USPM31310	
Sample Date		Client Info		14 May 2024	23 Apr 2024	18 Nov 2023	
Machine Age	hrs	Client Info		0	0	0	
Oil Age	hrs	Client Info		0	0	0	
Oil Changed		Client Info		N/A	N/A	N/A	
Sample Status				ATTENTION	ATTENTION	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>90	<1	9	7	
Chromium	ppm	ASTM D5185m	>5	<1	0	<1	
Nickel	ppm	ASTM D5185m	>5	<1	0	<1	
Titanium	ppm	ASTM D5185m	>3	<1	0	<1	
Silver	ppm	ASTM D5185m	>3	<1	0	0	
Aluminum	ppm	ASTM D5185m	>7	2	0	2	
Lead	ppm	ASTM D5185m	>12	<1	0	0	
Copper	ppm	ASTM D5185m	>30	<1	0	<1	
Tin	ppm	ASTM D5185m	>9	<1	0	0	
Vanadium	ppm	ASTM D5185m		<1	0	0	
Cadmium	ppm	ASTM D5185m		<1	0	<1	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	0	0	
Barium	ppm	ASTM D5185m	0	3	0	0	
Molybdenum	ppm	ASTM D5185m	0	<1	0	<1	
Manganese	ppm	ASTM D5185m		0	0	0	
Magnesium	ppm	ASTM D5185m	0	<1	<1	<1	
Calcium	ppm	ASTM D5185m	0	8	93	94	
Phosphorus	ppm	ASTM D5185m	1800	1845	393	446	
Zinc	ppm	ASTM D5185m	0	0	3	0	
Sulfur	ppm	ASTM D5185m	0	200	1457	1512	
CONTAMINANTS	;	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>60	6	<1	2	
Sodium	ppm	ASTM D5185m		14	2	<1	
Potassium	ppm	ASTM D5185m	>20	2	0	1	
Water	%	ASTM D6304	>.1	0.058	0.006	0.010	
ppm Water	ppm	ASTM D6304	>1000	585	66	103.7	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2	
Particles >4µm		ASTM D7647	>5000	8538	4697	4551	
Particles >6µm		ASTM D7647	>1300	1953	1087	1439	
Particles >14μm		ASTM D7647	>160	108	70	117	
Particles >21µm		ASTM D7647	>40	19	18	25	
Particles >38µm		ASTM D7647	>10	1	1	1	
Particles >71µm		ASTM D7647	>3	0	0	0	
Oil Cleanliness		ISO 4406 (c)	>19/17/14	20/18/14	19/17/13	19/18/14	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2	
A si al Niversia a v. (ANI)		ACTM DODGE	0.05	0.10	0.45	0.15	

0.18

mg KOH/g ASTM D8045 0.05

Acid Number (AN)

0.15

0.15



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No. Lab Number

: 06180172 Unique Number : 11031498

: USPM36157 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 15 May 2024 **Tested** : 16 May 2024

: 17 May 2024 - Doug Bogart Diagnosed

8295 ARENZVILLE RD BEARDSTOWN, IL US 62618

JBS - BEARDSTOWN

Contact:

T:

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)