




# PROBLEM SUMMARY

## Sample Rating Trend






WATER



Machine Id  
**CRYOVAC 8600-14CS LINE 8 (S/N CK3357U00145)**  
 Component  
**Gearbox**  
 Fluid  
**PETRO CANADA PURITY FG EP GEAR OIL 220 (--- QTS)**

## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	ABNORMAL
Aluminum	ppm	ASTM D5185m	>25	▲ 64	▲ 81	▲ 95
Water	%	ASTM D6304	>0.2	▲ 1.28	▲ 0.526	▲ 0.305
ppm Water	ppm	ASTM D6304	>2000	▲ 12800	▲ 5260	▲ 3050
Particles >4µm		ASTM D7647	>20000	▲ 53632	---	---
Oil Cleanliness		ISO 4406 (c)	>21/19/16	▲ 23/17/12	---	---
Emulsified Water	scalar	*Visual	>0.2	▲ 0.2%	0.2%	0.2%

Customer Id: SMIMID  
 Sample No.: USP0011877  
 Lab Number: 06180189  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

## HISTORICAL DIAGNOSIS

### WATER



#### 28 Feb 2024 Diag: Doug Bogart

We advise that you perform a filter service and use off-line filtration to improve the cleanliness of the system fluid. Else we recommend that you drain the oil from the component if this has not already been done. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles and water present in this sample. The aluminum level is abnormal. All other component wear rates are normal. Appearance is milky. There is a moderate concentration of water present in the oil. There is a moderate amount of visible silt present in the sample. The AN level is acceptable for this fluid.

[view report](#)



### WATER



#### 26 Nov 2023 Diag: Doug Bogart

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. The aluminum level is abnormal. All other component wear rates are normal. Appearance is hazy. There is a moderate amount of visible silt present in the sample. Elemental level of silicon (Si) above normal. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid.

[view report](#)



### DIRT



#### 23 Aug 2023 Diag: Doug Bogart

Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. Appearance is hazy. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid.


[view report](#)





# OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id  
**CRYOVAC 8600-14CS LINE 8 (S/N CK3357U00145)**  
 Component  
**Gearbox**  
 Fluid  
**PETRO CANADA PURITY FG EP GEAR OIL 220 (--- QTS)**

## DIAGNOSIS

### ▲ Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

### ▲ Wear

The aluminum level is abnormal. All other component wear rates are normal.

### ▲ Contamination

Appearance is milky. There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a high concentration of water present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>USP0011877</b>	USP0007555	USP0003808
Sample Date	Client Info	<b>14 May 2024</b>	28 Feb 2024	26 Nov 2023
Machine Age	mls	Client Info	0	0
Oil Age	mls	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>SEVERE</b>	ABNORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >200	<b>18</b>	22	22
Chromium	ppm	ASTM D5185m >15	<1	<1	0
Nickel	ppm	ASTM D5185m >15	<1	<1	<1
Titanium	ppm	ASTM D5185m	<1	<1	<1
Silver	ppm	ASTM D5185m	<1	0	0
Aluminum	ppm	ASTM D5185m >25	<b>64</b>	81	95
Lead	ppm	ASTM D5185m >100	<1	0	<1
Copper	ppm	ASTM D5185m >200	<b>7</b>	7	5
Tin	ppm	ASTM D5185m >25	<1	<1	<1
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<b>6</b>	10	14
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<1	<1	0
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	<b>2</b>	3	4
Calcium	ppm	ASTM D5185m	<b>257</b>	344	456
Phosphorus	ppm	ASTM D5185m	<b>205</b>	217	204
Zinc	ppm	ASTM D5185m	<b>0</b>	3	0
Sulfur	ppm	ASTM D5185m	<b>820</b>	746	752

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	<b>11</b>	23	58
Sodium	ppm	ASTM D5185m	<b>18</b>	40	50
Potassium	ppm	ASTM D5185m >20	<b>2</b>	<1	1
Water	%	ASTM D6304 >0.2	<b>1.28</b>	0.526	0.305
ppm Water	ppm	ASTM D6304 >2000	<b>12800</b>	5260	3050

## FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	<b>53632</b>	---	---
Particles >6µm	ASTM D7647 >5000	<b>1155</b>	---	---
Particles >14µm	ASTM D7647 >640	<b>32</b>	---	---
Particles >21µm	ASTM D7647 >160	<b>11</b>	---	---
Particles >38µm	ASTM D7647 >40	<b>1</b>	---	---
Particles >71µm	ASTM D7647 >10	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c) >21/19/16	<b>23/17/12</b>	---	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.51	<b>0.14</b>	0.154	0.249




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	▲ MODER
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	● MILKY	● MILKY	● HAZY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	▲ 0.2%	0.2%	0.2%
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	205.8	219	192

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : USP0011877  
**Lab Number** : 06180189  
**Unique Number** : 11031515  
**Test Package** : IND 2

**SMITHFIELD FOODS-MIDDLESBORO**  
 MIDDLESBORO, KY  
 US  
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: