

OIL ANALYSIS REPORT

Area AIRLUBE 228 [DA558] ATLAS COPCO APF211387 - F & P TROY

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend




NORMAL


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06180247		
Sample Date		Client Info		05 Apr 2024		
Machine Age	hrs	Client Info		9551		
Oil Age	hrs	Client Info		1987		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>5	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		<1		
Aluminum	ppm	ASTM D5185m	>15	11		
Lead	ppm	ASTM D5185m	>65	<1		
Copper	ppm	ASTM D5185m	>65	<1		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	1.5	0		
Barium	ppm	ASTM D5185m	0	2		
Molybdenum	ppm	ASTM D5185m	0	<1		
Manganese	ppm	ASTM D5185m	0.3	<1		
Magnesium	ppm	ASTM D5185m	0	0		
Calcium	ppm	ASTM D5185m	0	<1		
Phosphorus	ppm	ASTM D5185m	406	211		
Zinc	ppm	ASTM D5185m	0	84		
Sulfur	ppm	ASTM D5185m	1283	0		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	<1		
Sodium	ppm	ASTM D5185m		3		
Potassium	ppm	ASTM D5185m	>20	5		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.463	0.44		



OIL ANALYSIS REPORT

VISUAL





White Metal	scalar	*Visual	NONE	NONE			
Yellow Metal	scalar	*Visual	NONE	NONE			
Precipitate	scalar	*Visual	NONE	NONE			
Silt	scalar	*Visual	NONE	NONE			
Debris	scalar	*Visual	NONE	NONE			
Sand/Dirt	scalar	*Visual	NONE	NONE			
Appearance	scalar	*Visual	NORML	NORML			
Odor	scalar	*Visual	NORML	NORML			
Emulsified Water	scalar	*Visual	>0.1	NEG			
Free Water	scalar	*Visual		NEG			
FLUID PROPERT		method	limit/base	current	biotory1	history?	
Visc @ 40°C	cSt	ASTM D445	47.9	48.6	history1	history2	
					المرسمة ما ما		
SAMPLE IMAGES	5	method	limit/base	current	history1	history2	
Color				•	no image	no image	
Bottom					no image	no image	
GRAPHS							
Ferrous Alloys							
6 4 2 0 7 2 4			Apr5/24				
Non-ferrous Metal							
Apr5/24			Apr5/24 -				
Viscosity @ 40°C			(0,HO) X (0,HO) X (0,	Acid Number	r		
Apr5/24			Apr5/24	Apr5/24		Apr5/24 +	
American					AIR TECHNOLOGIES INC (MID) 400 WRIGHT AVE MIDDLETOWN, OH US 45044 Contact: Josh Oaks josh.oaks@aircompressors.com		

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

e (JCGM 106:2012) F: (513)539-6040 Contact/Location: Josh Oaks - UCAIRMID

To discuss this sample report,

Certificate L2367

Laboratory Sample No. Lab Number Unique Number Test Package

Page 2 of 2