

OIL ANALYSIS REPORT

Sample Rating Trend



Area **DPO** [9787] **KAESER 3610366 - AUTONATION COLLISION** Component Compressor

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	NATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UDI0000217	UCH05795969	
Sample Date		Client Info		08 May 2024	03 Mar 2023	
Machine Age	hrs	Client Info		96289	95683	
Oil Age	hrs	Client Info		605	2680	
Oil Changed		Client Info		Changed	Changed	
Sample Status				NORMAL	NORMAL	
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	2	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	3	7	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0.1	0	0	
Barium	ppm	ASTM D5185m	0.8	<1	4	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m	0.9	0	0	
Magnesium	ppm	ASTM D5185m	0	<1	1	
Calcium	ppm	ASTM D5185m	0	0	0	
Phosphorus	ppm	ASTM D5185m	409	252	229	
Zinc	ppm	ASTM D5185m	0	18	28	
Sulfur	ppm	ASTM D5185m	1290	1272	3196	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	1	
Sodium	ppm	ASTM D5185m		1	0	
Potassium	ppm	ASTM D5185m	>20	0	<1	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.537	0.30	0.42	



OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	NONE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	
Free Water	scalar	*Visual		NEG	NEG	
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	44.56	43.2	49.8	
SAMPLE IMAGES	;	method	limit/base	current	history1	history2
Color						no image
Bottom						no image
GRAPHS						
8 iron 6 diama chromium 7 diama chromium 7 diama chromium 7 diama chromium 8 diama chromium 7 diama chromium 8 diama chromium 9 diama chromium			May8/24			
Non-ferrous Metals	5		May824			
Viscosity @ 40°C				Acid Number		
55 Abnormal			@ ^{0.6}			
50 - Abnormal			9.0 2.0 Will 2.0 Wind KOH(d) 2.0 Nrmb Ber 1.0 Vind KOH(d) 2.0 Nrmb Ber 2.0 Vind KOH(d) 2.0 Vin	18		
45 Base			<u>ຍ</u> ິດ.3	36		
40 - Abnormal			4 0.2	24		
35			Acid 1	12		
			0.0	10		- 124 -
Mar3/25			May8/24	Mar3/23		May8/24
WearCheck USA - 501 UDI0000217 06180286 11031612 IND 2 ontact Customer Servic	Recei Teste Diagr	ved : 15 d : 16 losed : 17	6 May 2024 6 May 2024 May 2024 - V			TISS STREET IS GROVE, IL US 60515

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (630)960-3931

Report Id: UCDELDOW [WUSCAR] 06180286 (Generated: 05/17/2024 14:09:35) Rev: 1

Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** Test Package

Contact/Location: MICHAEL FERRIS - UCDELDOW

T: