




OIL ANALYSIS REPORT

Sample Rating Trend



DIRT



Area
METRO
 Machine Id
METRO 20011
 Component
Front Differential
 Fluid
 {not provided} (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. Please note that this is a corrected copy for laboratory data updates.

Wear

Gear wear is indicated.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. Elemental level of silicon (Si) above normal.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0934517	WC0828739	WC0692948
Sample Date	Client Info		02 Feb 2024	23 Jun 2023	21 Apr 2022
Machine Age	mls	Client Info	509018	458573	338801
Oil Age	mls	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >500	▲ 675	▲ 832	365
Chromium	ppm	ASTM D5185m >10	5	6	3
Nickel	ppm	ASTM D5185m >10	4	5	0
Titanium	ppm	ASTM D5185m	<1	<1	<1
Silver	ppm	ASTM D5185m	<1	0	0
Aluminum	ppm	ASTM D5185m >25	8	7	6
Lead	ppm	ASTM D5185m >25	<1	<1	<1
Copper	ppm	ASTM D5185m >100	4	4	2
Tin	ppm	ASTM D5185m >10	<1	0	0
Antimony	ppm	ASTM D5185m >5	---	---	---
Vanadium	ppm	ASTM D5185m	<1	<1	0
Cadmium	ppm	ASTM D5185m	<1	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	295	307	398
Barium	ppm	ASTM D5185m	1	0	0
Molybdenum	ppm	ASTM D5185m	2	1	<1
Manganese	ppm	ASTM D5185m	17	21	6
Magnesium	ppm	ASTM D5185m	3	7	3
Calcium	ppm	ASTM D5185m	26	26	14
Phosphorus	ppm	ASTM D5185m	2022	2113	2110
Zinc	ppm	ASTM D5185m	13	21	5
Sulfur	ppm	ASTM D5185m	26947	25056	20908

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >75	▲ 105	▲ 138	70
Sodium	ppm	ASTM D5185m	10	12	8
Potassium	ppm	ASTM D5185m >20	7	8	6
Water	%	ASTM D6304 >.2	0.040	0.062	0.063
ppm Water	ppm	ASTM D6304 >2000	400	629.0	633.4

FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 156245	▲ 159049	---
Particles >6µm	ASTM D7647	>5000	▲ 36245	▲ 37102	---
Particles >14µm	ASTM D7647	>640	553	135	---
Particles >21µm	ASTM D7647	>160	88	14	---
Particles >38µm	ASTM D7647	>40	1	0	---
Particles >71µm	ASTM D7647	>10	0	0	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 24/22/16	▲ 24/22/14	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	3.22	3.90	3.55



OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	81.5	62.9	70.9
Visc @ 100°C	cSt	ASTM D445	11.8	10.5	11.7
Viscosity Index (VI)	Scale	ASTM D2270	137	156	160

SAMPLE IMAGES

method	limit/base	current	history1	history2
Color				
Bottom				

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0934517 **Received** : 15 May 2024
Lab Number : 06180633 **Tested** : 17 May 2024
Unique Number : 11031959 **Diagnosed** : 18 May 2024 - Jonathan Hester
Test Package : MOB 2 (Additional Tests: KF, KV100, PrtCount, VI)

BASF - GIANNA CREDAROLI
 500 WHITE PLAINS RD
 TARRYTOWN, NY
 US 10591
 Contact: GIANNA CREDAROLI
 gianna.credaroli@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)