




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
METRO
 Machine Id
METRO 20007
 Component
Front Differential
 Fluid
{not provided} (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. Please note that this is a corrected copy for laboratory data updates to ICP data.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 6 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0934515	WC0828808	WC0728436
Sample Date	Client Info		01 Feb 2024	09 Jun 2023	20 Jul 2022
Machine Age	mls	Client Info	492859	446890	356182
Oil Age	mls	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ATTENTION	ATTENTION	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >500	472	468	399
Chromium	ppm	ASTM D5185m >10	3	4	3
Nickel	ppm	ASTM D5185m >10	2	5	3
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	2	3	2
Lead	ppm	ASTM D5185m >25	0	<1	0
Copper	ppm	ASTM D5185m >100	1	1	1
Tin	ppm	ASTM D5185m >10	0	0	0
Antimony	ppm	ASTM D5185m >5	---	---	---
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	47	51	47
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	<1	1	<1
Manganese	ppm	ASTM D5185m	7	7	6
Magnesium	ppm	ASTM D5185m	148	159	146
Calcium	ppm	ASTM D5185m	3	4	2
Phosphorus	ppm	ASTM D5185m	1653	1754	1490
Zinc	ppm	ASTM D5185m	2	0	5
Sulfur	ppm	ASTM D5185m	25688	29697	24926

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >75	56	53	48
Sodium	ppm	ASTM D5185m	7	7	6
Potassium	ppm	ASTM D5185m >20	2	5	<1
Water	%	ASTM D6304 >.2	0.043	0.041	0.051
ppm Water	ppm	ASTM D6304 >2000	430	418.9	518.3

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	25247	28677	51169
Particles >6µm	ASTM D7647	>5000	2324	2169	4158
Particles >14µm	ASTM D7647	>640	130	28	109
Particles >21µm	ASTM D7647	>160	27	7	19
Particles >38µm	ASTM D7647	>40	1	2	2
Particles >71µm	ASTM D7647	>10	0	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	22/18/14	22/18/12	23/19/14


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.07	1.13	0.86




OIL ANALYSIS REPORT


Particle Trend




Water (KF)




Viscosity @ 100°C



Water (KF)



Viscosity @ 40°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	48.0	47.9	48.3
Visc @ 100°C	cSt	ASTM D445	39.0	8.9	9.1
Viscosity Index (VI)	Scale	ASTM D2270	663	168	172

SAMPLE IMAGES

Color




Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0934515

Lab Number : 06180643

Unique Number : 11031969

Test Package : MOB 2 (Additional Tests: KF, KV100, PrtCount, VI)

Received : 15 May 2024

Tested : 22 May 2024

Diagnosed : 22 May 2024 - Jonathan Hester

BASF - GIANNA CREDAROLI

500 WHITE PLAINS RD

TARRYTOWN, NY

US 10591

Contact: GIANNA CREDAROLI

gianna.credaroli@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: