




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
KAESER SX 5 A/C 4619187 (S/N 1174)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KCPA006098	KC06005653	KCP54402
Sample Date	Client Info			14 Mar 2024	06 Oct 2023	16 Mar 2023
Machine Age	hrs	Client Info		57923	55494	52059
Oil Age	hrs	Client Info		0	0	3000
Oil Changed	Client Info			N/A	N/A	Not Changd
Sample Status				NORMAL	NORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	1
Chromium	ppm	ASTM D5185m	>10	<1	<1	0
Nickel	ppm	ASTM D5185m	>3	<1	<1	0
Titanium	ppm	ASTM D5185m	>3	<1	<1	0
Silver	ppm	ASTM D5185m	>2	<1	<1	0
Aluminum	ppm	ASTM D5185m	>10	2	2	<1
Lead	ppm	ASTM D5185m	>10	<1	<1	0
Copper	ppm	ASTM D5185m	>50	4	13	4
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	<1	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	19	<1	24
Molybdenum	ppm	ASTM D5185m		<1	<1	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	90	53	16	56
Calcium	ppm	ASTM D5185m	2	1	<1	1
Phosphorus	ppm	ASTM D5185m		1	6	5
Zinc	ppm	ASTM D5185m		6	0	11
Sulfur	ppm	ASTM D5185m		20621	18756	20174

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		10	5	23
Potassium	ppm	ASTM D5185m	>20	2	2	2
Water	%	ASTM D6304	>0.05	0.024	0.007	0.014
ppm Water	ppm	ASTM D6304	>500	246	73.5	149.5

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2234	3338	51820
Particles >6µm		ASTM D7647	>1300	631	927	▲ 18977
Particles >14µm		ASTM D7647	>80	32	57	▲ 1903
Particles >21µm		ASTM D7647	>20	7	16	▲ 455
Particles >38µm		ASTM D7647	>4	0	1	▲ 52
Particles >71µm		ASTM D7647	>3	0	0	▲ 4
Oil Cleanliness		ISO 4406 (c)	>--/17/13	18/16/12	19/17/13	▲ 23/21/18

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.32	0.20	0.28


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	44.6	46.1	43.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA006098 **Received** : 15 May 2024
Lab Number : 06180670 **Tested** : 18 May 2024
Unique Number : 11031996 **Diagnosed** : 18 May 2024 - Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, PrtCount)

OLD DOMINION
 5950 STICKNEY RD
 TOLEDO, OH
 US 43612
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)