


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# **KAESER 5160845**

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

### **DIAGNOSIS**

#### Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

The aluminum level is abnormal. All other component wear rates are normal.

#### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Apr202	1 0ct2021	Jun 2023 Ma	y2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA013559	KCPA005713	KCP39356
Sample Date		Client Info		09 May 2024	22 Jun 2023	06 Oct 2021
Machine Age	hrs	Client Info		39571	36486	32761
Oil Age	hrs	Client Info		4847	0	3760
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				ABNORMAL	NORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	<1
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	<1
Aluminum	ppm	ASTM D5185m	>10	<u> 11</u>	<1	<1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	2	7	9
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Antimony	ppm	ASTM D5185m				<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	8
Barium	ppm	ASTM D5185m	90	1	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	30	23	7
Calcium	ppm	ASTM D5185m	0	<1	0	<1
Phosphorus	ppm	ASTM D5185m	0	<1	1	2
Zinc	ppm	ASTM D5185m	0	22	35	14
Sulfur	ppm	ASTM D5185m	23500	24477	20777	17535
CONTAMINANTS	1	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	7	11	<1
Sodium	ppm	ASTM D5185m		2	2	<1
Potassium	ppm	ASTM D5185m	>20	4	<1	1
Water	%	ASTM D6304	>0.05	0.013	0.006	0.007
ppm Water	ppm	ASTM D6304	>500	136	60.9	74.3
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		7590	7789	6096
Particles >6µm		ASTM D7647	>1300	<b>2902</b>	1160	1608
Particles >14μm		ASTM D7647	>80	42	44	98
Particles >21µm		ASTM D7647	>20	8	10	17
Particles >38µm		ASTM D7647	>4	0	0	0
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/19/13	20/17/13	18/14
On Olcariii 1033		.0000 (0)	, , , , , , ,	20/13/13	=0, , . 0	



## **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No.

Lab Number : 06180672 Unique Number : 11031998

: KCPA013559

Received **Tested** Diagnosed

: 15 May 2024 : 18 May 2024

: 18 May 2024 - Jonathan Hester

Test Package : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: CASREN [WUSCAR] 06180672 (Generated: 05/18/2024 17:13:07) Rev: 1

RENO, NV

US 89503

T:

F:

11500 PRODUCTION DR

tennas@cascadedesigns.com

Contact/Location: S. TENNA - CASREN

Contact: S. TENNA